Bahria University
Discovering Knowledge

LAHORE CAMPUS
(An initiative of Pakistan Navy)

Ref # BULC/2026/IT/AILab/4031/UPS **Dated: 23th October 2026**

CORRIGENDUM

1. In continuation of advertisement published at PPRA Website vide **TS0000015557E** dated on 04th October 2026 for Purchase of following equipment:

Sr. #	Description
1	Purchase of 30KVA UPS + Installation

2. With reference to the pre-bid meeting held on 20 October 2026, the following clarifications shall also apply:

i. Approximately 30 meters of 16 mm², 4-core flexible copper cable shall be provided for UPS input and output connections from the UPS room to the designated lab.
ii. DB box is available at the site and shall be installed by the contractor. The contractor shall supply and install one 100A, 4-pole circuit breaker, and associated accessories as specified in the tender.
iii. The contractor shall provide 25 meters of 16 mm², single-core flexible wire for earthing, including the required earthing and boring work.
iv. The contractor shall provide and install 100 feet of 40 × 40 duct as specified in the tender.
v. The UPS shall provide a minimum backup time of 10 minutes at 100% load.
vi. Bidders may submit a Manufacturer Authorization Letter (MAL) or an Authorized Dealership Letter, as applicable, in accordance with the tender requirements.

3. All other terms and conditions of the original tender notice shall remain unchanged

4. For further information please contact on Phone Numbers 042-99233408-15 Ext: 217

PRESIDENT, PURCHASE COMMITTEE
BAHRIA UNIVERSITY LAHORE CAMPUS
47-C CIVIC CENTRE JOHAR TOWN, LAHORE
Tel: 042-99233408-15 Ext-217
Fax: 042-99233402