



GOVERNMENT OF PAKISTAN
COLLECTORATE OF CUSTOMS (ENFORCEMENT)
HYDERABAD

A-49, SITE Area, Hyderabad Ph:022-9250072 Fax:022-9250073



TENDER NOTICE FOR PROVISION AND INSTALLATION OF FIRE HYDRANT SYSTEM

Sealed bids are invited from reputed Suppliers, Contractors, or Firms duly registered with the Income Tax, Sindh Revenue Board (SRB), and Sales Tax Department for the provision and Installation of a Fire Hydrant System along with all essential equipments on "Turnkey basis" in the warehouses located at Sukkur and Hyderabad under the jurisdiction of the Collectorate of Customs Enforcement, Hyderabad.

SCOPE OF WORK

2. The successful bidder shall be responsible for the installation of Fire Hydrant System along with all essential equipments Turnkey basis in Warehouses at Hyderabad as per Annex-A and Sukkur as per Annex-B. All deliverables must strictly adhere to the quantities, quality standards, and technical specifications detailed in the attached Tender Documents (Annex-A and Annex-B).

Terms and Conditions

- i. Detailed tender documents, including technical specifications, quantities, and annexures, are available for download via the **E-PADS** portal on the official **PPRA website** and can also be collected from the Office of the Deputy Collector (HQ), Collectorate of Customs Enforcement, Hyderabad.
- ii. Sealed bids must be dropped in the Tender Box placed in the Procurement cell, Collectorate of Customs Enforcement, A-49 site area Hyderabad and to submit online bids on Epads through PPRA official website on or before **25.08.2026** up to 1400 hours. These bids will be opened on the same day at 1500 hours in the presence of bidders or so their authorized representatives who may like to witness the opening up of sealed tenders.
- iii. Following documents must be attached with the tender documents:
 - Copy of valid Sales Tax Registration.
 - Copy of valid Income Tax Registration.
 - Business Profile of last 3 years.
 - Authority letter showing the details of authorized person for administrative division.

- Copy of CNIC of the authorized person.
- An affidavit confirming that the company is not blacklisted any where.
- iv. The competent authority reserves the right to accept or reject any or all bids in accordance with the provisions envisaged under Rule-33 for PPRA Rules 2004.
- v. No bidder will be allowed to alter or modify his/her bid after opening of the bids.
- vi. No conditional bids will be accepted.
- vii. Rates should be both inclusive/exclusive of all taxes.
- viii. Pay Order/ bank draft in the name of Collectorate of Customs Enforcement, Hyderabad equivalent to Pak Rs. 200,000/- as call deposit.
- ix. Warranty: As per general universal standards.
- x. Incomplete quotations will not be considered in any case.

C.No.72(9)/Tender/fire Hydrant System/2026-27/ 758


Dated: 03.08.2026



Deputy Collector (I/Q)
Collectorate of Customs Enforcement
Hyderabad

Hyderabad				Annexure A	
S.No	Description	Size	Qty	Price (exclusive of taxes)	Price (inclusive of taxes)
1	Fire Hose Cabinet Size: 36x24x10 made by 18SWG MS sheet front Glass door lock epoxy powder coated mounted Fire Hose Pipe: Fire Hose Pipe with male female coupling gun metal brass alongwith 100 RFT high pressure hosepipe 20 Bar Working pressure & 50 Bar Busting pressure best quality With Jet Nozzle branch pipe made by Gun Metal Brass Complete in all respect. Make: EPDM CHINA or any other equivalent	1.5"	6.00		
2	Electric pump Water inlet: DN100mm Water outlet: DN100mm Flow rate: 250GPM Pressure: 7bar Power: 37kw Speed: 2900rpm Voltage: 380V/50HZ/3 phase. Diesel pump Water inlet: DN00mm Water outlet: DN65mm Flow rate: 250GPM Pressure: 7bar Power: 45kw Speed: 3000rpm Battery not included. Pressure regulating pump Water inlet: 50mm Water outlet: 50mm Flow rate: 50GPM Pressure: 7bar Power: 5.5kw Speed: 2900rpm Voltage: 380V/50HZ/3 phase Pump parts Control cabinet, Pipeline, Valves and others Make: Imported	250 GPM 7 Bar	1.00		
3	Fire Hose Cabinet Size: 36x24x10 made by 18SWG MS sheet front Glass door lock epoxy powder coated mounted Fire Hose Pipe: Fire Hose Pipe with male female coupling gun metal brass alongwith 100 RFT high pressure hosepipe 20 Bar Working pressure & 50 Bar Busting pressure best quality With Jet Nozzle branch pipe made by Gun Metal Brass Complete in all respect. Make: EPDM CHINA or any other equivalent Landing Valve Material: brass / aluminum, Inlet: 2.5" BSP male / female thread, Outlet: 2.5" BS336 adaptor, With cover and chain Gun Metal Popular Brand	2.5"	3.00	Nos	



4	Pillar Type Hydrant Made Of SCH 40 seamless Pipe with Inlet: 4" and Outlet: 2 x 2.5" Hydrant Valve (Imported China). Make: China	4"	3.00	Nos	
5	Gate Valve PN 16 Ductile Iron NRS Spindle, EPDM Seat GCON Best Quality Made: Imported	3"	8.00		
6	Gate Valve PN 16 Ductile Iron NRS Spindle, EPDM Seat GCON Best Quality Made: Imported	4"	1.00		
7	Fire Brigade Breeching Inlet 1) Bottom Flange: 6inch 2) Outlet: 2.5 inch BS336 adaptor×4 3) Material: ductile cast iron body, brass check valve with cap 4) With drain gate valve Make: Imported	2way	1.00		
8	Non Return Valve Flange Type PN 16 MAKE: China	3"	2.00		
9	Non Return Valve Flange Type PN 16 MAKE: Imported	4"	1.00		
10	Pressure Relief Valve Complete with connection flanges SS made Make: JK Korea	2"	01.00		
11	Foot Valve/ Strainer Make: China	4"	01.00		
12	Test & Drain Valve CHINA 1) Material: brass valve, SS sight glass 2) Nominal Diameter: DN25 3) Inlet: BSP female thread 4) Outlet: BSP female thread 5) K factor: K5.6(80) or K8(115)	DN 25	02.00		
13	Fire Pump Pressure Gauge ULFM Listed Made: Imported	Nos	4		
14	Butterfly Valve Gear Operated Manually They are easier to use under high pressure Have better sealing performance Body: Ductile iron, stainless steel disc	4"	4		
15	High Pressure Ball Valve intended to manage high-pressure fluids while also allowing for free flow of the fluid.	Nos	6		



16	Supply, Installation and Commissioning of MS Schedule 40 seamless pipes (ASTM) fitting that's includes epoxy coating for corrosion resistant inside and outside, hole reservation, drilling and plugging, pipe cutting, beveling, straightening, bending, hole tapping and connecting pipe, reducing pipe manufacturing and installation, casing manufacturing and installation, hangers and support fabrication and installation, support derusting and painting, hydrostatic testing, balancing and flushing, pipe sleeves and all other necessary accessories. All aspects shall be in good condition complete in all respect. Make: Local or Imported	2-1/2" (65mm)	380.00		
17	Supply, Installation and Commissioning of MS Schedule 40 seamless pipes (ASTM) fitting that's includes epoxy coating for corrosion resistant inside and outside, hole reservation, drilling and plugging, pipe cutting, beveling, straightening, bending, hole tapping and connecting pipe, reducing pipe manufacturing and installation, casing manufacturing and installation, hangers and support fabrication and installation, support derusting and painting, hydrostatic testing, balancing and flushing, pipe sleeves and all other necessary accessories. All aspects shall be in good condition complete in all respect. Make: Local or Imported	3" (80mm)	170.00		
18	Supply, Installation and Commissioning of MS Schedule 40 seamless pipes (ASTM) fitting that's includes epoxy coating for corrosion resistant inside and outside, hole reservation, drilling and plugging, pipe cutting, beveling, straightening, bending, hole tapping and connecting pipe, reducing pipe manufacturing and installation, casing manufacturing and installation, hangers and support fabrication and installation, support derusting and painting, hydrostatic testing, balancing and flushing, pipe sleeves and all other necessary accessories. All aspects shall be in good condition complete in all respect. Make: Local or Imported	4" (100mm)	720.00		
19	Execution and Backfilling for underground piping	-	Job		
20	Installation, testing & commissioning of Fire Fighting Pump & Accessories, all fittings and fixing accessories complete in all respects.	Job	1.00		
21	Complete Transportation, Food & Accommodation for worker during installation of fire alarm system.	LumSum	1.00		
Total					

SUKKUR**Annexure B**

S.No	Description	Size	Qty	UOM	Price (exclusive of taxes)	Price (inclusive of taxes)
1	Fire Hose Cabinet Size:36x24x10 made by 18SWG MS sheet front Glass door lock epoxy powder coated mounted Fire Hose Pipe: Fire Hose Pipe with male female coupling gun metal brass along with 100 RFT high pressure hose pipe 20 Bar Working pressure & 50 Bar Busting pressure best quality With Jet Nozzle branch pipe made by Gun Metal Brass Complete in all respect. Make: EPDM CHINA or any other equivalent	1.5"	6.00	inch		
Fire Fighting Equipment's						
2	Electric pump Water inlet: DN100mm Water outlet: DN100mm Flow rate: 500GPM Pressure: 8bar Power: 37kw Speed: 2900rpm Voltage: 380V/50HZ/3 phase Diesel pump Water inlet: DN80mm Water outlet: DN65mm Flow rate: 500GPM Pressure: 8bar Power: 45kw Speed: 3000rpm Battery not included Pressure regulating pump Water inlet: 50mm Water outlet: 50mm Flow rate: 50GPM Pressure: 7bar Power: 5.5kw Speed: 2900rpm Voltage: 380V/50HZ/3 phase Pump parts Control cabinet, Pipeline, Valves and others Make: Imported	500 GPM 8 Bar	1.00	Nos		
3	Fire Hose Cabinet Size:36x24x10 made by 18SWG MS sheet front Glass door lock epoxy powder coated mounted Fire Hose Pipe: Fire Hose Pipe with male female coupling gun metal brass along with 100 RFT high pressure hose pipe 20 Bar Working pressure & 50 Bar Busting pressure best quality With Jet Nozzle branch pipe made by Gun Metal Brass Complete in all respect. Make: EPDM CHINA or any other equivalent Landing Valve Material: brass / aluminum, Inlet: 2.5" BSP male / female thread , Outlet: 2.5" BS336 adaptor, With cover and chain Gun Metal Popular Brand	2.5"	4.00	Nos		

4	Pillar Type Hydrant Made Of SCH 40 seamless Pipe with Inlet: 4" and Outlet: 2 x 2.5" Hydrant Valve (Imported China). Make: China	4"	4.00	Nos		
5	Butterfly Valve Gear Operated Manually They are easier to use under high pressure Have better sealing performance Body: Ductile iron, stainless steel disc Make: China	4"	4.00	Nos		
6	Non Return Valve Flange Type PN 16 MAKE: Imported	4"	1.00	No		
7	Pressure Relief Valve Complete with connection flanges SS made Make: JK Korea	2"	1.00	Nos		
8	Foot Valve/ Strainer Make: China	DN150	1.00	Nos		
9	Fire Pump Pressure Gauge ULFM Listed Made: Imported	-	2.00	Nos		
10	Test & Drain Valve CHINA 1) Material: brass valve, SS sight glass 2) Nominal Diameter: DN25 3) Inlet: BSP female thread 4) Outlet: BSP female thread 5) K factor: K5.6(80) or K8(115)	DN25	2.00	Nos		
11	Gate Valve PN 16 Ductile Iron NRS Spindle, EPDM Seat GCON Best Quality Made: Imported	2"	6.00	Nos		
12	Fire Brigade Breaching Inlet 1) Bottom Flange: 6inch 2) Outlet: 2.5 inch BS336 adaptor x4 3) Material: ductile cast iron body, brass check valve with cap 4) With drain gate valve Make: Imported	2way	1.00	Nos		
13	High Pressure Ball Valve intended to manage high-pressure fluids while also allowing for free flow of the fluid.	Nos	6.00	--		

