Pakistan State Oil Company Limited
PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan
Telephone (021) 9203866-85 Fax (021) 9203796

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)
SAP No.6100018907

RFQ No	QA-20180MS
DATE	05.11.2026

Company PSO Dummy Vendor
PAKISTAN

QUOTATION REQUIRED

ON (Date)	20.11.2026	BY (Time)	

Please quote your best price for all items of following specifications. Please read the instructions attached herewith EARNEST MONEY % Rs._____ PO/DD NO. _____

Title: Supply and Installation of 06 KVA UPS for ZOT, LMT, FSD <(>&<)> Sihala Laboratories.

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
1	**UPS Inverter (6KV)** - Automatic UPS Inverter System - Make: - Model: - Origin: - Capacity: 06 KVA - Input: Single Phase - Voltage: 220/230/240 VAC - Acceptable Voltage Range: 170 - 280 VAC - Frequency Range: 50 / 60 Hz Auto Sensing - PV Input: 8 KW minimum - Output: Single Phase - Voltage: 230 / 240 VAC - Power Factor: 0.9 or above - Transfer Time: 10 ms (Suitable for computers and sophisticated equipment) - Output waveform: Pure/true sine wave - Frequency Range: 50 Hz - Over-voltage and overload protection - Backup time: At least 60 minutes on full load - Efficiency: = at least 90% - Alpha-Numeric Display which displays system parameters and alarms - Built-in battery management system (BMS) through RS-485 / RS-232 communication. - Bypass option available - Display Parameters: Utility power/inverter Connected load Input voltage Output voltage Battery Percentage Charge Control: Built-in MPPT Charge controller up to 120A AC charge controller Floating Charge voltage: 54 V DC	**PSO House**	**EA**	4		

Pakistan State Oil Company Limited
PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan
Telephone (021) 9203866-85 Fax (021) 9203796

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)
SAP No.6100018907

RFQ No	QA-20180MS
DATE	05.11.2026

Company PSO Dummy Vendor
PAKISTAN

QUOTATION REQUIRED

ON (Date)	20.11.2026	BY (Time)	

Please quote your best price for all items of following specifications. Please read the instructions attached herewith EARNEST MONEY % Rs._____ PO/DD NO. _____

Title: Supply and Installation of 06 KVA UPS for ZOT, LMT, FSD <(>&<)> Sihala Laboratories.

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
	Overcharge Protection: 66-volt DC - Battery: Type: Lithium-ion Battery Battery Voltage: 48-to-56-volt DC Capacity: 10 KW Operating temperature: 0ºC to 40ºC Manufacturer Warranty for Inverter and Battery: At Least 03 Years. - Supplier will provide complete Installation of units at PSO Laboratories (ZOT Laboratory, LMT Laboratory, Faisalabad Laboratory, and Sihala Laboratory) - Number of Days (from Issuance of PO: Max.60 Days					