



NRTC

TENDER NOTICE

No. Proc: TU-5094-2026

Sealed bids are invited from reputable firms/ distributor/ suppliers for procurement of the following.

S.No	Description	Qty.	Unit
1	Fire Suppression System Detail attached as Annex-A	01	No

Notice: Tender Procedure: Single Stage Two Envelop Basis.

- Delivery FOR **NRTC Haripur**.
- The complete Tendering process shall be carried out through EPADS 2.0 Version .
- Price inclusive and exclusive of taxes need to be mentioned separately. (Supplier must be active tax payer otherwise bid will be treated as cancelled).
- **Rs 40,000/-** as a bid security in shape of Pay Order/Demand Draft in favor of NRTC Haripur. Scanned copy of bid security is required to be uploaded through EPADS 2.0 Version.
- Financial health of the firm must be attached (**Ref Form # 4**) tender documents attached.
- Price must be quoted in PKR.
- **Warranty:** Standard warranty.
- **Bid Validity:** 90 days.

As per PPRA Rules NRTC may reject all bids or proposals at any time prior to the acceptance of a bid or proposal.

Bids complete in all respect should reach the office of the under signed up to **26 Oct,2026** till 1130 hours and Bids will be opened at 1200 hours on same day.

HOD (PROCUREMENT)

NATIONAL RADIO AND TELECOMMUNICATION CORPORATION, HARIPUR

Tel: 0995-666584, 0995-666657 Fax: 0995-610933

Email: proc.local@nrtc.com.pk,

Web Site: www.nrtc.com.pk

Annex-A

S.No	Technical Compliance Requirement	Minimum Requirement / Standard	Marks	Obtained Marks
1	Overall system architecture	Addressable fire alarm integrated with clean agent suppression	10	
2	In-house certified installer	Bidder must be certified installer and supplier for this addressable smoke and heat detection and Extinguishing system	10	
3	Manufacturing and origin	EU,Us only	5	
4	Applicable fire standards	EN 54-2 and EN 54-4 series compliance	1	
5	International certifications	UL / FM / Vds approvals	1	
6	Device capacity	Minimum 250 devices per loop	1	
7	Power supply & battery backup	Built in PSU with ≥ 24 hrs standby	1	
8	Smoke detection technology	Optical smoke detection	2	
9	Heat Detection capability	EN 54 complaint heat sensing	2	
10	Event log memory	Capacity to store up to 20,000 events	1	
11	Manual call points	Addressable MCPs complaint with EN 54	1	
12	Audio / Visual Alarm Devices	Addressable sounder/ Flasher	1	
13	Gas Suppression agent	Clean agent suitable for server rooms	1	
14	Gas Actuation & Safety	Automatic & Manual release with safety features	1	
15	Installation, Testing & Commissioning	Complete installation, testing & training	1	
16	Warranty & after sales support	Minimum 1 year warranty & support	1	
Total Marks			40	