



CLARIFICATION# 2 / EXTENSION# 1

ASSORTED VALVES

TENDER ENQUIRY# SSGC/FP/PT/14306

Dear Sir,

This refers to the above mentioned tender enquiry, one of the prospective bidder have raised a query and the response to that query is being forwarded to all the prospective bidders to maintain the transparency.

S.#	Bidder's Query	SSGC's Response
1	Body Construction (Fully Welded vs. Bolted) Please confirm whether all ball valves are strictly required to be of fully welded body construction, and whether bolted body construction is completely unacceptable for this project.	<i>Offered Ball Valve Body should be Fully Welded body construction.</i>
2	Double Block & Bleed (DBB) vs. Trunnion Mounted with DPE Seats Please confirm whether all ball valves shall be of: Option A: Double block and bleed (DBB) design with double piston effect (DPE) seats; or Option B: Trunnion-mounted ball valves with DPE seats (with or without DBB functionality).	<i>All offered Ball Valves shall be Trunnion-mounted type with Double piston effect (DPE) seats and shall provide double block and bleed (DBB) functionality as per SSGC Technically Specification Clause # 6.2.1.2.2 accordingly .</i>
3	Seating Material Combination (Soft Seat & Metal Seat Ring) Please confirm whether the required seating arrangement is soft seated (e.g., RPTFE) with a metal seat ring (e.g., ASTM A182 F316). If not, kindly advise the acceptable combination.	<i>All offered Ball Valves shall be a primary metal seat and secondary soft seat arrangement, preferably for sales gas service. The bidder shall provide full details of the seat arrangement. Seat materials shall be compatible with the gas composition in accordance with SSGC Technical Specification Clause 1.2.2.5.</i>
4	Welded Connections to Valve Body Your specification states: "Connections to the valve body shall be welded." Please clarify whether this refers to end connections (e.g., butt-weld ends), as well as isolation and drain valves being directly welded to the main valve body.	<i>Valve body connections shall be welded; seal-welded and threaded connections are not permitted. Pressure sensing, drain, and pressure relief connections shall comply with API 6D and SSGC Technical Specification Clauses 2.6.1.2.7, 2.6.1.2.8, and 2.6.1.2.9, respectively.</i>
5	Acceptable Carbon Steel Materials for Fully Welded Valves For fully welded carbon steel ball valves, please confirm whether ASTM A105 (standard service) and ASTM A350 LF2 (low-temperature service) are acceptable.	<i>Both the specified material standards comply with API 6D requirements for the offered ball Valves. ASTM A350 LF2 preferably.</i>
6	Non-Destructive Testing (NDT) Requirements Please clarify whether the following NDT methods will be required at the factory for fully welded ball valves: • Radiographic Testing (RT) • Ultrasonic Testing (UT) • Penetrant Testing (PT) • Magnetic Particle Testing (MT)	<i>All Non-Destructive Testing (NDT) shall be performed in accordance with the SSGC Technical Compliance Sheet Inspection and Testing Requirements, Clause No. 9, including all its sub-clauses.</i>
7	Hydrostatic / Functional Test (FET) Please confirm whether a hydrostatic pressure test (FET) is required for each fully welded ball valve prior to shipment	<i>Yes. The hydrotest shall be conducted in accordance with the SSGC Technical Specification Sheet, Clause 6.2.1.2.1 and all related sub-clauses and submit all documents related Hydrostatic test to SSGC along with signed and stamped.</i>
8	Body Construction (Fully Welded vs. Lubricated Type) Please confirm whether plug valves are not required to be fully welded, and instead shall be of lubricated type design.	<i>Plug valves under this specification shall be of Lubricated Type and Regular Pattern, in accordance with the SSGC Technical Specification Sheet, Clause 6.2.1.1 and all its sub-clauses.</i>

Further, the bid submission date of the subject tender enquiry has been extended up to "08-June-2026 15:00 Hrs." instead of existing.

Please note that in case if the bid bond validity fall short of 150 days due to extension in bid submission date, the bidders are liable to extend the bid bond validity up to 150 days within 30 days of the opening of technical proposals.

Important Note: All prospective bidders who intend to submit bid against the subject tender enquiry and want to submit bid bond in shape of Bid Bond Guarantee, the format of Bid Bond Guarantee should be same as the format of Bid Bond given in the tender document else the bid will be liable for rejection.

All other terms & conditions will remain unchanged.

Inconvenience caused is highly regretted please.

For General Manager (P)

ASSORTED VALVES

FOB/C&F & FOR (Only for Local Manufacturers SRO 827(1)/2001)

*Bids are to be invited on Under Single Stage Two Envelope Bidding Procedure
Under PPRA Rules 2004, Rule# 36 (b)*

TENDER ENQUIRY NO:
SSGC / FP / PT / 14306

Bid Closing date & time: 21-05-2026 at 1500 Hrs.

Bid Opening date & time: 21-05-2026 at 1530 Hrs.

Fixed Bid Security; USD=1,270,000 OR PKR=360,000.

Note: Tender document is also available online on SSGC website for view only. Bidder is eligible to participate in bidding process only after purchasing the tender documents from Tender Room SSGC Head Office under the procedure mentioned in the Press Publication / SSGC website.

It is mandatory for bidders to attach original Token Slip in front of the Sealed Envelope (issued at the time of Purchasing) as an evidence that supplier has purchased the Tender documents. Further, any Corrigendum/Clarifications/Addendums/Extensions issued to be notified to only those bidders who have purchased Tender documents.

Venue:

Tender Room, CRD Building, Ground Floor
SSGC Head office complex Karachi -75300
Ph.99021024 – 99021173 - 99021116.



Sui Southern Gas Company Limited

Procurement Department, 2nd Floor, ST-4/B, Block-14, Sir Shah Suleman Road, Gulshan-e-Iqbal,
Karachi-Pakistan. Phone: 99021231, 99021223, Fax: 99231583 www.ssgc.com.pk/ssgc

Checklist for Bidders

Enquiry No. _____ Opening Date _____ Time _____
 M/s. _____ Phone No. _____

Please ensure before submitting the bid, that following information / documents have been submitted / provided along your bid. Check () appropriate box.

S. No.	Details of required information / documents	Yes	No
1.	Each & Every Page of the bidding documents shall be signed and stamped by the bidder.		
2.	Technical Compliance sheet (if applicable) has been filled		
3.	Fixed Bid Bond as specified in the tender document.		
4.	Bid validity as specified is mentioned		
5.	Delivery period has been specified		
6.	Country of Origin		
7.	Standard Warranty Guarantee (if applicable)		
8.	Original Performa Invoice of Principal		
9.	Original Technical Literature		
10.	Original Authorization Letter of Principal		
11.	Original Authorization Letter of Manufacturer		
12.	Estimated item wise weight including gross weight & volume of consignments		
13.	Port of Shipment (specific name of Air / Sea Port is required) In case the city mentioned by the bidder does not have any port, the FOB charges to the port of shipment will be borne by the supplier.		
14.	L/C confirmation charges (if desired by bidder) shall be borne by the supplier		
15.	L/C charges at supplier's end shall be borne by the supplier		
16.	Both FOB & C&F rates are quoted (C&F rates should be based on PNSC freight)		
17.	Sample (if necessary) is enclosed		
18.	Alternative offer (if any) submitted should be on as per Section 3 Schedule of Requirement & Bid Form format. For each alternative offer separate fixed bid bond is required.		
19.	Deviations from tender terms (if any) have been stated in Section 3 Schedule of Requirement & Bid Form format. At any stage of process and after accordingly Tender terms will prevail.		
20.	Firm name of Beneficiary & Bank details with complete address of beneficiary.		
21.	Original Bid + One Copy is Submitted		
22.	Form-X and bid securing declaration Duly Signed & Stamped.		

NOTE:

Non-availability of the above information/documents, or incomplete/incorrect statement on this checklist may result in rejection of the bid at / after the bid opening.

As per SRO296(I)/2023 dated 08th March 2023 "E-Pak Procurement Regulations, 2023" all bidders are advised to register in e-Pak Acquisition and Disposal System (EPADS).

 Bidders Authorized Representative



Sui Southern Gas Company Limited (SSGCL)

Contents

Part – A

Section – 1	General Terms & Conditions	Included
Section – 1A	Additional Terms & Conditions for FOB/C&F	Included
Annexure–A	Format of Bid Bond Bank Guarantee	Included
Annexure–B	Format of Performance Bank Guarantee	Included
Annexure–C	Declaration by Supplier	Included
Section – 2	Special Conditions of Tender Document	Included /Not required

Part – B

Section – 3	Bid Form (Schedule of requirement)	Included
Section – 4	Specifications/Drawing (if applicable)	Included/Not required
Section – 5	Affidavit of Compliance with Integrated Management System (IMS) Manual	Included

SSGC

SUI SOUTHERN GAS COMPANY LIMITED
Procurement Department

M/s. _____

Tender Enquiry No. _____

INVITATION TO BID

Sui Southern Gas Company Limited, (SSGCL) has pleasure in extending you an invitation, to submit bid for the subject material according to Terms and Conditions specified in the attached Tender Document. Please read following instructions before submission of bid:

1. Bids are to be submitted in sealed envelope provided with the tender, indicating Tender Enquiry Number & its opening date and time on the face of the envelope.
2. Bid Bond @ 5% of the total FOR / FOB value shall be enclosed with the bid without which bid will be rejected and returned to bidder unannounced. The Bid Bond shall remain valid till the last date of the month in which it is expiring.
3. In case the bid opening date falls on a holiday or due to some unavoidable circumstances, it is not possible to open on scheduled date, it will be opened on next working day at the same time and at the same venue.
4. The bidder shall bear all expenses associated with the preparation and delivery of its bid/sample and the Company will in no case be liable in this respect.
5. Prospective bidder requiring any information or clarification of the tender may notify the same by fax or at the mailing address. The Company will respond to any request for explanation or clarification, if received within reasonable time prior to submission of bids.
6. The Company reserves the right to cancel, add, delete or amend tendered items/quantities/any part of the tender during the bidding period without assigning any reason. However, bidders shall be informed about it prior to bid opening/process.
7. The Company reserves the right to accept or reject any bid or part of a bid or to annul the bidding process and reject all bids at any time prior to award of contract/purchase order without thereby incurring any liability to the affected bidder(s).
8. In case of Single stage two (02) envelope bidding procedure (as mentioned in press advertisement & Tender document), sealed technical offer & sealed bid shall be submitted in separate envelopes Bid Bond will be enclosed with "commercial" bid. "Technical Proposal" and "Financial Proposal" is to be mentioned on the top of the envelope. Technical offers will be opened and evaluated first. Financial offers of only technically compliant bidders will be opened at a later intimated date in presence of bidder's representatives. Financial proposal of technically non-compliant bidders will be returned un-opened along with their bid bond.
9. For Tenders invited on F.O.B/C&F basis, conditions as mentioned in Section 1A will also apply.
10. The Company will appreciate confirmation by fax No 92-21-99231583 or email mmte@ssgc.com.pk or to DGM (Procurement) of your intention to submit the bid and if not interested in submission of bid, it will be appreciated if it is intimated through fax or email with mentioning of reasons.
11. Bids are required to be submitted at:

Tender Room, CRD Building, Head Office Complex, Sir Shah Suleman Road Gulshan-e-Iqbal, Karachi Pakistan. Ph. 0092-21-99021024, 0092-21-99021223, 0092-21-99021279, 0092-21-99013074, Fax # 0092-21-99231583, Email: mmte@ssgc.com.pk

Hope and look forward for your valued participation.

Thanking you

Yours sincerely


General Manager (Procurement)



General Terms & Conditions

1. Submission of bids:


- 1.1. Bids are to be submitted in sealed envelope provided with the tender (in such a manner that contents are fully kept enclosed and cannot be seen until opened) indicating tender enquiry number, its opening date and time on the top of the envelope. Envelopes shall be addressed to General Manager (Procurement Department) on the address provided on "invitation to bid". Envelope shall indicate the name and address of the bidder for returning the bid in case it is declared late or submitted without bid bond.
- 1.2. Sealed bids (as above) shall be mailed/submitted/dropped in tender box placed at Tender Room, CR Building, SSGC Head Office. Bids are to be delivered on or before closing time after which bid will not be entertained. In case bid is sent through courier, the same shall be delivered at least half an hour before scheduled opening time.
- 1.3. The Company may at its discretion extend the closing date for the submission of bids, in which case all rights and obligations of the purchaser and bidders previously subject to the closing date will thereafter be subject to the date extended. However, any request for extension received from prospective bidders less than one week prior to bid opening date may not be entertained. In case of extension in bid opening date, the same will be advertised in press and simultaneously shall be intimated to prospective bidder who had purchased the tender documents.
- 1.4. The bid shall contain no underlines, erasures or overwriting except as necessary to correct the errors made by the bidder, in case of any correction etc. it shall be signed and stamped by the person signing the bid.
- 1.5. The quoted price shall be inclusive of all duties/taxes except GST, which is to be mentioned separately. The supplier shall declare (if applicable) regarding non-applicability of GST for which documentary evidence shall be enclosed or could be produced upon demand.
- 1.6. Rates shall be item-wise, as given in prior schedule/schedule of requirement/Bid Form unless otherwise specified.
- 1.7. Bidder is responsible for timely delivery of bids at location specified 1.2 above. Company will not be responsible for misplacement/ tampering/ non-attendance/delay or any other incident in case the bid is not delivered at the designated place & time.
- 1.8. Any bid received late after the closing date and time, will be rejected and returned unopened.
- 1.9. The quotation shall only be acceptable on/as per Bid Form. In case for foreign tender when Local Agent submits bid on behalf of different bidders, a separate Bid Bond for each Bid is required. Likewise for tender when bidder submit alternative bids a separate bid bond for each bid is required or else bid will be liable for rejection.
- 1.10. Deviation from tender terms and conditions is not allowed. However, in unavoidable circumstances, these shall be mentioned at the bottom of "Section 3: Bid Form" deviation on any other page will not be entertained.
- 1.11. Discount offered (if any) shall be mentioned on the "bid form" only.
- 1.12. The bidder(s) or their authorized representative shall put his full signature and stamp & date on each page of tender document as well as enclosure vis-a-vis drawings, specifications etc. Any correction, overwriting shall be duly signed & stamped.
- 1.13. The bid is to be completed and returned to the Company in accordance with, General terms & conditions. General terms & conditions duly signed & stamped (as a token of acceptance) shall be submitted along with Bid Form (Price schedule) duly completed as per requirement. However, specifications/drawing is to be retained by bidder for their future references.

2. Eligible Countries / bidders:

The invitation for bids is open to all manufacturers/suppliers/stockiest/dealers/pre-qualified bidders but is not applicable to those countries where inter trade protocols with Pakistan do not exist or those countries from where imports are not allowed by Government of Pakistan.

3. Qualification/Disqualification of Suppliers:

The Company, at any stage of the procurement proceedings, having credible reasons for or prima facie evidence of any defect in supplier's or contractor's capacities, may require the suppliers or contractors to provide information regarding their professional, technical, financial, legal or managerial competency,



whether already pre-qualified or not. The Company shall disqualify a supplier or contractor if it finds, at any time that the information regarding their qualification as supplier or contractor was false and materially inaccurate or incomplete. **Black Listing Mechanism**

4. **Joint Ventures:**

In the event that the successful bidder is a joint venture (formation of two or more companies), the Company will require an undertaking on judicial stamp paper that the parties to the joint venture accept joint and several liabilities for all obligations under the purchase order/contract.

5. **Clarification of tender documents:**

Prospective bidders requiring any further information or clarification of the tender documents may notify, the Company in writing or by fax or at the Company's mailing address indicated in the "invitation to bids". The Company will respond in writing to any request for information or clarification of the tender documents, if received five working days prior to closing date for the submission of bids prescribed by the Company. The Company response (including an explanation of the query) will be sent in writing or by fax/e-mail to all prospective bidders who have purchased the tender documents. Verbal instructions/reference will not be acceptable.

6. **Modification and withdrawal of bid:**

- 6.1 The bidder may modify or withdraw its bid after the bid submission, provided the written notice of the modification or withdrawal is received by the Company prior to the deadline prescribed for submission of bid. After the bids/quotations are opened, no bidder shall be allowed to revise, propose or request any change in the bid.
- 6.2 The bidder's modification or withdrawal notice shall be sealed and addressed to GM (P). A withdrawal notice may be sent by fax followed by a signed copy.
- 6.3 Bids once opened cannot be withdrawn during validity period.

7. **Bid validity:**

All offers shall remain valid up to 90 days (120 days in case of Two Envelope bidding procedure) from the date of opening of bids, until any further extension agreed by the bidder. If the bidder agrees for extending bid validity the bid bond shall also be extended accordingly. Bidder giving extension to his bid validity will not be required or permitted to modify his bid. If there will be any query/clarification or extension request asked by the Company, the bidder should reply the same within 7 days after receipt of the same and if bidder takes more than 7 days the delay in reply will be added to their bid validity period.

8. **Rate Escalation:**

8.1 **All items except line-pipe:**

Quoted prices shall remain valid, firm, irrevocable and fixed till the fulfillment of obligations by the bidder and will not be subject to escalation / change on any account.


8.2 **Line-pipe only:**

8.2.1 Bidders are essentially required to submit detailed breakdown of rates indicating price of:

- HR Coil
- All other charges (including wastage, transportation, conversion cost etc).

8.2.2 Rate / price offered by the bidders shall be firm and irrevocable. However bidder offering pipe manufactured from Pakistan Steel Mills (PSM) HR coil are required to submit certified documentary evidence of HR coil rates. Adjustment in line-pipe rates (from the bid opening date till the currency of order) due to change in rate of HR coil manufactured by PSM is admissible to the extent of raw material cost without wastage. The bidders are required to submit certified documentary evidence of HR coil rates published by PSM, at the time of submission of bids. SSGC may verify the document / rates from PSM.

8.2.3 The variation clause however shall not be applicable on line-pipe quantities which were delivered within 20 days of the announcement of the variation (both days inclusive) in price of HR coil by PSM.



8.2.4 The variation clause also shall not be applicable on the line pipe quantities delivered after the specified delivery schedule (total or monthly consignment wise)

8.2.5 No escalation is applicable on line pipe manufactured from imported HR coil.

9. **Bid bond (earnest money):**

Bid bond equivalent to two percent (2%) of the total offer value, in favor of Sui Southern Gas Company Ltd. shall accompany the bid if bid value is above Rs.500,000 in the form of pay order, demand draft, call deposit receipt or a bank guarantee (specimen of bank guarantee is attached at Annexure-A), issued by a scheduled bank in Pakistan. The bid bond shall remain valid for 120 days (150 days in case of Two Envelope bidding procedure) unless specified otherwise. The bid bond shall be returned/refunded to the unsuccessful bidders while the bid bond of the successful bidder shall be retained, till submission of Performance bond (if applicable). Bids without bid bond will not be considered. In case the order value is less than Rs. 500,000 the bid bond in lieu of performance bond will be retained till fulfillment of obligations by the supplier. However, in either case the bidder is responsible to arrange the extension the bid bond validity as per requirement. If bid bond submitted by the supplier is more than 2% of ordered value, it may be replaced with appropriate value. If order value is less than Rs. 500,000, the bid bond will be returned along with the order. Bid bonds of non-compliant bidders may be released during evaluation process. The bid bond may be forfeited if a bidder withdraws the bid during validity period specified by the bidder or if successful bidder fails to:

- ✓ Accept purchase order.
- ✓ Furnish performance guarantee in accordance with clause 16 of Section 1,
- ✓ Supply material as per requirements and delivery schedule.

9.1 In the event of bid bond validity following end of the prescribed period of 120 or 150 days as the case may be either (i) due to extension in the bid submission date or (ii) where so required by the procuring agency, then in such an event it shall be mandatory on the bidder to extend the bid bond validity upto 120/150 days within 30 days of the opening of technical proposal / bid, and /or where so required by the procuring agency.


9.2 In the event of the bid security amount deposited / furnished by the bidder falls short by 10% of the requisite Bid security amount. The procuring agency keeping in view the nature of the procurement may consider and allow the bidder to deposit / furnish the balance 10% amount, provided the bidder does so within 15 days of the opening of the bid. Notwithstanding that all other terms & conditions have been fully complied with.

10. **Opening of bids:**

Bids will be opened in presence of bidders or their authorized agents at the address provided on "invitation to bids". The bidder's representatives who are present shall sign the bid opening sheet (attendance sheet) to mark their attendance/witness. Commercial contents of bids will be announced/recorded in bid opening sheet.

11. **Preliminary Examination of bids:**

- 11.1 The Company will examine the bids to determine their completion, computational errors, provision of guarantees, authorized signature and other related matters.
- 11.2 Arithmetic errors will be rectified on the following basis. Discrepancy between unit price and the total price obtained by multiplying the unit price and quantity, the unit price shall prevail and the total price will be corrected. Discrepancy between total bid amount and the sum of total prices, the total prices shall prevail and the total bid amount will be corrected.
- 11.3 Prior to a composed evaluation, the Company will determine the substantial responsiveness of each bid to the bidding documents. In Company's opinion a substantially responsive bid is the one which conforms to all the terms and conditions of the bidding documents without any material deviation.
- 11.4 Bid determined as not substantially responsive will be rejected by the Company and cannot subsequently be made responsive by the bidder through correction of the non-conformity.



12. Clarification of submitted bids:

To assist in the examination, evaluation and comparison of bids, the Company may at its discretion inquire any clarification from bidder about their bid. All responses by bidders shall be provided in writing and no change in the price or substance of the bid shall be sought, offered or permitted.

13. Technical Literature & Samples:

The Bidder(s) shall submit the following:

- 13.1 Samples (if applicable/required)
- 13.2 Original or legible copy of technical literature/performance characteristics
- 13.3 Test Certificates (if applicable/required)
- 13.4 Documentary evidence for legal import in case of imported material. (At the time of delivery when quoted on FOR basis)
- 13.5 In case of pipeline operation material bidders must also attach a "proof from supplier/ manufacturer, that goods offered have been used successfully on a high pressure natural gas pipeline elsewhere under tropical climatic conditions.

13.6 Specification Compliance Sheet:

Company requires clause-by-clause commentary on the Specifications, demonstrating the materials responsiveness to those specifications or a statement of deviations and exceptions to the provisions of the specifications, as required/desired. For purposes of the commentary to be furnished pursuant to above, the bidder shall note that standards for workmanship, material and equipment and references to brand names or catalogue numbers, designated by the Company in the specifications are intended to be descriptive only and not restrictive. The bidder may substitute other authoritative standards, brand names and/or catalogue numbers in its bid provided which demonstrates to the Company's satisfaction that the substitutes are equivalent or superior to those designated in the specifications by the Company.

Bid which does not possess above documents, certificates etc., may be considered technically Non-compliant.


- 13.7 The offer shall be accompanied with all technical data/documents/certifications as required under the tender specifications. Evaluation shall be carried out on the basis of data/ documents/certifications submitted with the bid. No clarification, additional information may be sought / accepted after bid opening.

13.8 Deviation to technical specifications:

The bidder shall fill the "technical compliance sheet" and mention offered specifications along with reference to its technical brochure/literature (page/clause No.etc). Statement such as "Compliant" or "Confirmed" is not acceptable. Deviation to tender terms and technical specification is not acceptable. However, if bidder feels to mention minor deviation, the same shall be referred categorically on the "Bid Form" as well as on the technical compliance sheet with reference of its technical data sheet/brochure. In case of insufficient information, data or documents, the Company is not liable to seek clarification and the bid may be determined non-compliant, provided information.

14. Award/Evaluation Criteria:

- 14.1 In case of locally manufactured items e.g. service line material & meter components, manufactured by local vendors, the lowest bidder will be awarded maximum quantity as per his declared capacity and past performance in respect of delivery and quality. New vendors / manufacturers shall also be considered for placement of a purchase order up to a maximum of 10% of the tender quantity if their submitted sample has been tested and approved and provided they have quoted lowest price or agree to accept the order on lowest received price.
- 14.2 Generally for other items other than above, ordering shall be based on technical compliance and lowest quoted price. Supplies may be subject to pre shipment inspection and post qualification by a third party in case of foreign material. If required during the process of manufacturing and / or inspection, SSGCL representative may visit the manufacturer facility to witness the manufacturing / inspection process.



- 14.3 Evaluation may be carried out both on item or on group of items/single or multiple package basis depending upon the nature of requirement exclusively at the discretion of the company to ensure economic procurement.
- 14.4 Company reserve the right to settle the final terms of supply with the lowest evaluated and commercially responsive bidder. Any effort by the bidder (s) to influence the outcome of bid evaluation or placement of purchase order may result in disqualification of the bidder.

15. Loading of Bids:


Bids may be loaded with following if offer found to be deviated from specifications, delivery schedule, terms & conditions without stating the amount involved in such deviation by following method:

- 15.1 The cost of compensation / loading amount for that item shall be derived from the bid itself.
- 15.2 If 15.1 is not possible, average of rates of other bidders, who have quoted for that item conforming to technical specification, shall form the basis for cost compensation/loading.
- 15.3 The company will encourage participation by local bidders who will be given price preference. Landed cost factor shall be determined as per prevailing Government policy / SRO. However they will submit details of local value addition on raw material imported by them and percentage of locally manufactured component with documentary evidence.

16. Performance Bond:

- 16.1 In case purchase order value is above Rs:500,000, the successful bidders shall submit performance bond guarantee which is to be submitted within ten days from receipt of LOI or order along with integrity pact. The successful bidders shall submit a performance bank guarantee (PBG) in the form of a pay order or bank guarantee specimen attached at Annexure-B) issued by a scheduled bank in Pakistan, for an amount equivalent to 10% of the total value of the purchase order or as specified, in the "letter of intent". The performance bond unless specified otherwise; shall remain valid till;
- 16.1.1 Completion of final satisfactory delivery in case of consumable items.
- 16.1.2 12-18 months from the date of satisfactory delivery of the equipment/machinery.
- 16.1.3 Satisfactory delivery/installation of system in case the installation responsibility is on supplier's part.
- 16.1.4 120 days in case of chemicals.
- 16.1.5 In case of locally manufacturing item, the PBG equivalent to 3 months delivery schedule will be required after placement of purchase order which should remain valid till completion of final satisfactory delivery of the ordered quantity.
- 16.1.6 In case of small diameter line pipe (MS/MDPE) the PBG shall remain valid up to 3 months after completion of satisfactory final delivery.
- 16.1.7 In case of Vehicles, Manufacturer's Warranty is required in lieu of PBG.
- 16.2 The guarantee will be released after completion of this period, subject to satisfactory performance of the supplied equipment/machinery/system as mentioned at 16.1 above. The supplier shall keep the guarantee valid at their cost until fulfillment of the obligations.
- 16.3 In case the bidder does not submit the performance bond as specified, the delivery time of goods shall be deemed to have commenced 10 days (15 days in case of import) from the issuance of letter of intent/purchase order. The proceeds of the performance bond shall be payable to the Company as compensation for any loss resulting from the supplier's failure to complete its work under the purchase order/ contract. The validity period of the performance bond is to be extended if the delivery date/period is being extended mutually by the Company/Supplier.
- 16.4 The performance bond will be discharged / returned by the Company not later than thirty (30) days following the date of completion of the supplier's work under the purchase order/contract including any warranty/guarantee/performance obligations as specified in the special conditions of contract. The supplier shall not be absolved of their liability to perform in case of encashment of performance bond by the Company, who shall have the right to claim and receive all damages/losses incurred due to non-performance.
- 16.5 The Company shall promptly notify the supplier in writing for any claim arising under this guarantee. Upon receipt of such notice, the supplier shall promptly repair or replace the defective goods or parts thereof, without cost to the Company other than, where applicable the cost of inland delivery of the repaired or replaced goods or parts from the port of entry to the final destination.

14.



- 16.6 If the supplier, having been notified, fails to rectify the defect (s) in accordance with the purchase order/contract, the Company may proceed to take such remedial actions as may be necessary at the supplier's expense. Any amount payable by the supplier under this clause may be recovered by the Company by withdrawing from the performance bond without having to notify or seek the approval of the supplier.
- 16.7 Nothing herein contained shall be construed to limit supplier's obligation of performance of the order/contract to the value of the performance bond.
- 16.8 **Guarantee/Warranty:** In case where performance guarantee is not applicable, the supplier shall confirm that all supplied goods under the contract/purchase order are new, unused, of the most recent or current models and incorporate all recent improvements in design and goods unless provided otherwise in the contract/purchase order. This guarantee shall remain valid for a period of twelve to eighteen months after the goods have been delivered or commissioned.
17. **Purchase Order/Contract:**
Purchase order of noted material may be placed on fulfillment of conditions mentioned at 14 & 16 above which is through a formal confirmation for proceedings with the suppliers.
18. **Assurance:**
The successful bidder will be required to give satisfactory assurance of its ability and intention to deliver the goods, pursuant to the tender enquiry and contract within the time set forth therein.
19. **Force Majeure:**
- 19.1 In the event of either party hereto being rendered unable, wholly or partially, by force majeure circumstances to carry out its obligations under the purchase order/contract documents, such party shall give notice and full particulars and other satisfactory evidence of such force majeure circumstance(s) in writing or by fax to the other party within 7 days after the occurrence of the cause(s). Relied upon the obligations of the party giving such notice so far as they are affected by such force majeure shall be suspended for the period during cause(s) shall, as far as possible, be remedied and obviated with all reasonable dispatch. The term 'force majeure' as employed herein, shall mean acts of God or public enemy, civil insurrection, fires, floods, earthquakes or other physical disasters, order or request of government, blockade or embargo. It is, however, clarified that strikes, lockouts, shortage or non-availability of raw materials, rains, and disturbances, other labor dispute or congestion's in ports on the supplier's side shall not be included in the term 'force majeure'.
- 19.2 In case the force majeure contingencies last continuously for more than one month, both parties will agree on the necessary arrangements for the further implementation of the purchase order/contract. In case further implementation is unforeseeable and not possible, both parties shall arrange for the termination of the purchase order/contract, but without prejudice to their rights and obligations prior to such termination it being understood that each party shall fulfill its contractual obligations so far as they have fallen due before the operation of force majeure.
20. **Amendment in purchase order/contract:**
- 20.1 The Company may at any time by a written notice to the supplier make changes within the general scope of the purchase order/contract in any one or more of the following:-
- 20.1.1 Drawings, designs or specifications where goods to be furnished under the purchase order/contract are to be specifically manufactured for the Company.
- 20.1.2 The method of shipment or packing.
- 20.1.3 The place of delivery.
- 20.1.4 Quantities of item up to a maximum variance of +15% of purchase order/contract value.
- 20.2 Company reserves the right to increase/decrease the quantities or delete any or all items listed in the price schedule/schedule of requirement/bid form without assigning any reason.
- 20.3 Upon notification by the Company of such modifications the supplier shall submit to the Company an estimated cost for the proposed modification within ten (10) calendar days of receipt of notice of the modification and shall include an estimate of the impact (if any) of the modification on the delivery dates under the purchase order/contract, as well as a detailed schedule for the execution of the modification, if applicable.



- 20.4 The supplier shall not perform modification in accordance with clause 20.1 above until the Company have authorized a modification order in writing on the basis of the estimate provided by the supplier as described in clause 20.3.
- 20.5 Modification mutually agreed upon shall constitute a part of the work under the purchase order/contract and the provisions and conditions of the contract shall apply to the said modification.
- 20.6 If modification made by the Company results in a variation in purchase order/contract quantities whose net cost effect is within 15% of the total value then the original purchase order/contract rates would be applicable. Any "modification" affecting the quantities and the corresponding cost effect beyond 15 percent would be mutually agreed upon between the Company and the supplier.

21. Extension of delivery period:


- 21.1 Delivery of the goods shall be made by the supplier in accordance with the schedule of requirements and delivery period; however, the supplier may claim extension of the time limits as set forth in the schedule of requirements and delivery period in case of
- 21.1.1 Modification in the goods ordered by the Company pursuant to clause 20.
- 21.1.2 Delay in provision of any services which are to be provided by the Company (services provided by the Company shall be interpreted to include all approvals by the Company under the contract).
- 21.1.3 Delay in performance of work caused by orders issued by the Company.
- 21.2 The supplier shall demonstrate to the Company's satisfaction that it has used its best endeavors to avoid or overcome such causes for delay and the parties will mutually agree upon remedies to mitigate or overcome such causes for delay.
- 21.3 Notwithstanding clause 21.1 above, the supplier shall not be entitled to an extension of time for completion unless the supplier at the time of such circumstances arising, immediately has notified the Company in writing of any delay that it may claim as caused by circumstances pursuant to clause 21.1 above and upon request of the Company, the supplier shall substantiate that the delay occurred is due to the circumstances referred by the supplier.

22. Packing:

- 22.1 The material shall be in original/sealed packing to ensure delivery without any damage during transit.
- 22.2 If any of the good is discovered to be damaged or unacceptable at the point of embarkation, the supplier shall be responsible for replacement of those goods free of any charge and cost to the Company, within the delivery time schedule of the contract/purchase order.
- 22.3 The identification marks showing contents, quantity and contract/purchase order number shall be printed on each skid/metal container/case containing one copy of invoice & packing list.
- 22.4 Handling and Transportation:
The Supplier shall arrange for the proper stacking of the Goods and for its proper storage and lashing and for other such provisions/suitable measures as may be necessary to safeguard against movement and damage to the Goods from the point of loading to its designated destination.

23. Inspection:

- 23.1 Pre-delivery inspection may be carried-out at the premises of supplier(s) and/or post delivery inspection at company's any location, by the appointed inspector/inspection team, third party inspectors appointed by the Company.
- 23.2 The Company reserves the right to arrange inspections and tests to the goods or manufacturing processes at any stage at any of the premises of the supplier or its subcontractor(s) or and at the point of delivery end at the goods final destination. Where conducted on the premises of the supplier or its sub-contractor(s), all reasonable facilities and assistance including access to drawings and production data shall be furnished to the inspectors at no charge to the Company. Such inspection, however, shall not relieve the Supplier to fulfill the obligations under the



purchase order/contract. If goods fail to conform to the specifications, the Company may reject them.

24. Delivery:


- 24.1 Free delivery at any of the following locations, unless specified otherwise:
- 24.1.1 R & D Section, Stores Department Abul Hasan Ispahani Road, Karachi.
 - 24.1.2 R & D Section, Stores Department F-37, SITE Karachi.
 - 24.1.3 R & D Section, Stores Department F-76, Dope Yard SITE, Karachi.
 - 24.1.4 Meter Manufacturing Plant, Sir Shah Suleman Road, Gulshan-e-Iqbal Karachi.
 - 24.1.5 Khadeji Store, 57th Kilometer at Super High way Karachi.
 - 24.1.6 Any other location specified by the company.
- 24.2 Delivery period shall commence after 10 days (15 days in case of import) of the issuance of letter of intent or from the date of purchase order/contract whichever is earlier, unless otherwise specified.
- 24.3 The supplier shall replace defective material at their risk & cost including transportation, duty, taxes etc.
- 24.4 GST Invoice if applicable be submitted at R&D section Stores Department along with material & delivery challan.
- 24.5 Unloading and stacking through cranes, fork lifters, labor etc. will be arranged by supplier at delivery site (for material like Pipes/Heavy Machinery & Equipment etc).
- 24.6 Delivery is to be made strictly in accordance with "delivery schedule" as specified by the Company.
- 24.7 The rejected material is to be collected/lifted by the supplier within a maximum period of one month after its intimation by the Company. Beyond specified period, the Company shall not be responsible for storage/safety of the uncollected material.

25. Delivery Failure:

- 25.1 In case the supplier fails to supply/ship the material within the stipulated period, the Company have the right to make an alternative arrangement for the purchase of the goods on such terms as may be offered. In such event all losses, cost and charges sustained/incurred by the Company on stated purchase shall be recovered from the Supplier without prejudice to any other right or remedy available to the Company which includes recovery of losses sustained by the Company from any due payment of the said supplier.
- 25.2 In the event Company remains unable to make such alternative arrangements, the Company has the right to recover from the supplier any or all losses sustained as a result of the supplier's failure to ship/supply the goods as per schedule of delivery.
- 25.3 In the event Company being forced to purchase any quantity or any other alternative not specified in this document as a result of any failure to supply/ship the material, the Company shall have the right to terminate the contract/purchase order without prejudice to any other rights or remedies available to the Company.

26. Payment:

- 26.1 The supplier after delivery of goods and its acceptance shall submit invoice to Finance Department of the Company, containing following information i.e.
- (a) Purchase order No. & date
 - (b) Items
 - (c) Quantity
 - (d) Price
 - (e) Invoice value
 - (f) Point of delivery
 - (g) Delivery challan indicating delivery date, etc.
- Payment will be made within 30 days of completion of stated formalities.
- 26.2 Income Tax @ 3.5% or as applicable under the prevailing government rules will be deducted at source (except where the supplier provides an income tax exemption certificate). Quoted price shall be inclusive of all taxes, except GST, which shall be mentioned separately. Supplier(s) are required to submit signed and stamp acknowledgement slip, Sales Tax return, Annex "C" & Annex "I" (whichever applicable), in which Sales Tax (of relevant Sales Tax invoice) is paid.




- 26.3 In case supplier is not liable to pay tax under the income tax ordinance or is liable to pay tax at a lower rate the supplier shall obtain a certificate from the tax authorities in Pakistan to that effect. In case the required certificate is not produced by the supplier prior to the date of payment, then the Company shall deduct tax at source from the gross payment payable to supplier.

27. Liquidated damages:

- 27.1 If supplier fails to deliver ordered material within the stipulated period/scheduled time specified in purchase order, Company, without prejudice to any other remedies, shall deduct from the bill or any other due payments/guarantees, as liquidated damages, a sum equivalent to 0.1% per day of the undelivered goods up to maximum 10%. The liquidated damages shall also be applicable for the cancelled quantity of goods under clause 28.
- 27.2 Whenever liquidated damages become payable, in the event that delivery of all goods and equipment is not made within the time period specified except on account of force majeure, the Company shall quantify the same and shall serve notice to the supplier requiring payment thereof. If the supplier fails to remit payment within 15 days of receipt of such notice, the Company shall forthwith become entitled to recover the same without recourse to the supplier, by calling upon The Performance Bond, withdrawals by way of liquidated damages shall not reduce the value of the Performance bond.
- 27.3 The payment of liquidated damages shall not relieve the supplier from performing and fulfilling all its obligations under the contract/purchase order nor shall the right and entitlements of the Company be affected or reduced in any manner.
- 27.4 In case of order placed on FOB/C&F basis, the delivery period shall commence from the date of confirmation of L/C. However, delayed submission of PBG period in excess of time limit will be deducted from the delivery period for the purpose of recovery of late delivery charges.
- 27.5 The liquidated damages shall be the sum equivalent to point one (0.1%) percent of the Contract price of the delayed goods as unperformed services for each day of delay, until actual delivery or performance, up to a maximum deduction of ten (10) percent of the Contract price. Once this maximum is reached, the Company may consider termination of the Contract at the risk and cost of the Supplier.

28. Default by Supplier:

- 28.1 The Company may, without prejudice to any other remedy, by written "notice of default" sent to the supplier, cancel the purchase order whole or in part; if:
- 28.1.1 The supplier fails to deliver any or all of the ordered quantity as per specified delivery schedule or any extension thereof granted by the Company.
- 28.1.2 The supplier fails to perform any other obligation(s) under the "purchase order".
- 28.1.3 The Company during the delivery period has reasons to believe that the supplier will not be able to fulfill the obligations under the purchase order/contract. The Company prior to exercising its right to cancel the purchase order/contract shall issue notice to the Supplier specifying the default(s) and the supplier shall submit an explanation within seven (07) days of receipt of such notice. If such explanation is not furnished within the stipulated time or if so furnished, is found to be unsatisfactory and/or the default(s) continues, purchase order/contract may be cancelled. The Company in addition to cancellation of purchase order/contract may suspend/cancel the enlistment of supplier.
- 28.2 The Company shall have the right to terminate/cancel the contract/purchase order concluded between the supplier and Company; if:
- 28.2.1 The successful bidder fails to furnish the performance bond as under clause 16 thereof.
- 28.2.2 The supplier fails otherwise to perform, fulfill or comply with terms, conditions, regulations and requirements of the contract/purchase order to carry out the work in accordance with the provisions thereof or abandons the shipment.
- 28.2.3 The supplier becomes bankrupt or insolvent or makes an assignment for the benefit of its creditors.
- 28.2.4 One or more consignments of material delayed by a period of more than three months or non-supplied.
- 28.2.5 Rejection of manufacturing items as a result of observation by inspection team



28.2.6 Penalty on higher rejection rate of supplied goods.

28.3 The supplier shall have the right to terminate the contract/purchase order if:-

28.3.1 The Company fails to establish the "letter of credit" within the stipulated period as required.

28.3.2 The Company becomes bankrupt or insolvent or makes an assignment for the benefit of its creditors.

28.3.3 The Company is in default and breach of its obligation and liabilities under the contract/purchase order.

29. **Resolution of dispute:**

The Company and the supplier shall make every effort to resolve the disagreement or dispute arising between them amicably by direct discussion under or in connection with the purchase order/contract.

30. **Applicable law:**

The purchase order/contract shall be governed by and interpreted in accordance with the laws of the Islamic Republic of Pakistan.

31. **Declaration/Integrity Pact/Certification:**

31.1 Successful supplier shall furnish the declaration (specimen attached at Annexure-C) within 10 days after issuance of PO/ order /contract if the order/contract value becomes Rs:10 million or above.

31.2 In case of F.O.B/C&F Purchase Order/Contract, the Principal as well as "local agent" both will sign the "integrity pact" as required under this clause.

31.3 Bidders to submit a certificate of Rs:100/- non-judicial stamp paper certifying that they are not black listed by the Government/Autonomous bodies and declared as defaulted supplier.

32. **Arbitration/resolution of disputes:**

32.1 Any difference or dispute arising out of or in connection with the contract between the Company and the supplier which can not be amicably resolved shall be referred to arbitration in Karachi, Pakistan, to two arbitrators, one appointed by each party of such difference/ dispute. In case the judgment of the said Arbitrator being at variance, the matter shall be referred to an "umpire", who shall be appointed by both the side Arbitrators. The umpire shall be retired judge of a High Court or the Supreme Court of Pakistan. Such arbitrators and umpire shall together proceed to adjudicate the disputes in accordance with the Arbitration Act, 1990, as amended from time to time.

32.2 Prior to exercising any right by the Company or supplier to terminate the purchase order/ contract under the conditions stipulated above, a return notice shall be required to be given to the other party specifying such default(s) and calling for submission of an explanation within seven (7) days of receipt of such notice. If such explanation is not furnished within the stipulated time or if so furnished, is found to be unsatisfactory, and the default(s) continues the purchase order/contract be terminated with notice to other party.

32.3 The agreement shall be governed by Law of Islamic Republic of Pakistan and the arbitration language shall be English.

32.4 During the course of arbitration, the supplier shall not suspend the performance of his responsibilities and obligations under the contract unless authorized by the Company in writing to do so.

32.5 In addition to the remedies as stated above, there is a "grievance committee" formed by the Company which can be approached by supplier in case of non-settlement of issues at any stage if supplier feels that settlement is not insight or not justified.

33. **Redressal of grievances by the procuring agency:-**

33.1 Grievance Committee is in place to address the complaints of bidders that may occur prior to entry into the procurement contract.

33.2 Aggrieved bidder may lodge a written complaint concerning his grievances not later than fifteen days after the announcement of the bid evaluation report.

33.3 Bidder is to submit complaint on letter head duly signed by the authorized person. Tender reference, details / nature of complaint, complainant active telephone, cell, postal address, email



address must necessarily be provided. Incomplete / anonymous complaints will not be responded at all.

- 33.4 The Committee shall investigate and decide upon the complaint within fifteen days of the receipt of the complaint
- 33.5 Mere fact of lodging of a complaint shall not warrant suspension of the procurement process.
34. **Blacklisting of Suppliers and Contractors:**

The Company shall permanently blacklist or temporarily debar (at least for 6-months from participating in SSGC's tender proceedings) if, a supplier or contractor who either constantly fails to perform satisfactorily performance or found to be indulged in corrupt and fraudulent practices as defined below:

- 34.1 "Corrupt and fraudulent practices" includes the offering, giving, receiving, or soliciting of anything of value to influence the action of an official/Company.
- 34.2 If the supplier/contractor found responsible for the detriment of the Company during proceedings of procurement/contract, process or its execution.
- 34.3 Misrepresentation of facts in order to influence the procurement process or the execution of the purchase order/contract.
- 34.4 Collusive practices among bidders (prior to or after bid submission) designed to establish bid prices at artificial, non-competitive levels and to deprive the Company of the benefits of free and open competition.
35. **Supplier's Guarantee and Responsibilities:**


The Bidder/Supplier shall guarantee that the materials supplied against this tender enquiry is new and is of acceptable quality and has been tested and approved on similar jobs. The validity and scope of such guarantee will be in accordance with conditions stated in this document. In case the opinion of the Company the Goods fail to perform the services in accordance with the specifications specified in Section IV, due to manufacturing defects/defective material and/or workmanship, the Supplier shall replace, repair or reconstruct such Goods at his own cost in Pakistan wherever the Goods shall be located so that such Goods shall be restored to such conditions that it shall perform in satisfactory operating condition or to replace it with new Goods at Supplier's cost so that the goods shall perform in accordance with the specifications and details as set forth in the Contract/tender documents. If the Supplier shall fail to do so after expiry of 15 days notice to the effect served on him by the Company, the Company shall be at liberty to repair, replace and/or reconstruct the Goods at its costs provided in the event, the Company shall be entitled to recover total cost of such replacement from the Supplier withdrawing from the Performance Guarantee.

36. **Language:**

The bid prepared by the bidder and all correspondence and documents relating to the bid exchanged by the bidder and the Company shall be written in English language. Any printed literature furnished by the bidder may be written in another language provided that this literature is accompanied by an English translation in which case for purpose of interpretation of the bid, English translation shall govern.

37. **Vehicle Applied by Authorized dealer of local manufacturer :**

In case of vehicle supplied by authorized dealer of local manufacturer, the authorized dealer will be responsible to get the vehicle (s) registered through Excise Department Government of Sindh and provide Original Registration book / Original Registration Invoice / Tax payment receipt / other related documents & provide the vehicle (s) number plate (s) to SSGC. Registration fee will be reimbursed by SSGC subject to submission of Government of Sindh Excise Department receipt.



Additional Terms for Tenders on F.O.B.JC&F basis:

1. Submission of bids:

- 1.1 Bid bond (Earnest money) @ 2% of the total F.O.B value as per clause 9, of section 1 of "General terms & conditions" is required to be submitted with the bid. It may be noted that bids without bid bond will be rejected and returned to bidder.
- 1.2 In case the bidder is manufacturer the bid shall either be completely prepared by the foreign bidder including signing and stamping of all documents. In case, such documents are being signed by the local agent of the bidder, the bid shall essentially include supplier's original Performa invoice and an original authority letter in favor of local agent to sign the documents on their behalf. The bid is liable for rejection if these conditions are not met.
- 1.3 In case of Bidder offering to supply goods which the bidder did not manufacture or otherwise produce, the bidder shall be fully authorized by the goods manufacturer or the producer to submit bid or supply the goods on their behalf.
- 1.4 Bids shall be submitted (preferably through local agents) in two copies, (original + copy).
- 1.5 The price on unit FOB and JC&F basis is to be quoted separately. Following are to be essentially indicated in the bid form:
- 1.5.1 Country of origin.
- 1.5.2 Port of shipment.
- 1.5.3 Estimated gross/net weight, dimension & volume of offered item and estimated weight of each item.
- 1.5.4 Delivery period or schedule in case of bulk quantities.
- 1.5.5 Original technical literature.
- 1.5.6 Beneficiary's complete address.

1.6 Foreign bank charges and L/C confirmation charges will be borne by the supplier.

1.7 Bid Currency:

The rates shall be quoted in bidder's home country or United States Dollars. A bidder expecting to incur a portion of its expenditures in the performance of the contract in more than one currency and wishing to be paid accordingly shall indicate the same in their bid. However, bidder from Pakistan would be paid in Pak Rupee.

(Clause 1.5 of General Terms & Conditions is not applicable)

2. Bid bond:

- 2.1 Bid bond shall be equivalent to two percent (2%) of the total F.O.B value in favor of Sui Southern Gas Company Limited and shall be in the form of pay order, demand draft, cash deposit receipt or a bank guarantee (specimen attached at Annexure-A), issued by a scheduled bank in Pakistan. The bid bond shall remain valid for 120 days (150 days in case of Single Stage Two Envelope Bidding procedure) unless specified otherwise. The bid bond shall be returned/refunded to the un-successful bidders while the bid bond of the successful bidder shall be retained, till submission of Performance bond. Bids without bid bond will not be considered. In case the order value is less than US\$25,000 the bid bond in lieu of performance bond, will be retained till fulfillment of obligations by the supplier. However, in either case the bidder is responsible to arrange the extension of bid bond validity as per requirement. If bid bond submitted by the supplier is more than 2% of ordered value, it may be replaced with appropriate value. Bid bonds of non-compliant bidders may be released during evaluation process. The bid bond shall be denominated in the currency of the bid or any other freely convertible currency.

2.2 Bid submitted on behalf of different principals shall be required to submit separate bid bond along with the bid for each offer.

(Note as mentioned at Clause 9, 9.1 & 9.2 of General Terms & Conditions shall also apply).

3. Conversion to single currency:

In order to carry out evaluation and comparison, the Company will convert all bid prices expressed in various currencies to Pak Rupees at the buying exchange rates established by the State Bank of Pakistan or any other commercial bank in Pakistan for similar transactions on the date of opening of bids; In case of Two Envelope Bidding System, the exchange rates prevailing at the time of opening of Technical Proposals will be used for conversion and evaluation.



4. Evaluation Criteria:

- 4.1 The evaluation of bids will be carried out on C&F / landed cost basis, however purchase order will be placed on FOB price on freight to collect basis. The bidders are required to submit best freight charges obtained by them from Pakistan National Shipping Corporation (PNSC) in order to have a uniform basis to arrive at C&F cost. Bill of lading to indicate "freight payable by the consignee at destination" in local currency. Foreign currency exchange rate (selling) will be considered as of bid "opening date".
- 4.2 In the case of goods to be offered from outside Pakistan, custom duties and other similar import taxes which are applicable shall be added to the bid.
- 4.3 In case shipment by air it shall be arranged through Company's airfreight forwarder (s) or their nominated agent. "on freight to collect basis".

(Clause No. 14.3 to 14.4 of General Terms & Conditions are also to be applicable).

5. Loading of Bids.

Freight charges from port of loading up to Karachi port or unit C&F value must be indicated in bid form, failing which bid will be loaded by 5 to 10% freight charges. Bid will be declared non-compliant if loading results an extensive increase in price of material.

(Clause 15 of General Terms & Conditions is also applicable).

6. Performance bond:

- 6.1 In case purchase order value is US\$ 2,000/- or above or equivalent for other currencies, letter of intent will be issued to successful bidders for submission of performance bond guarantee which is to be submitted within 15 days from receipt of L.O.I. All successful bidders shall submit a performance bank guarantee (P.B.G) in the form of bank guarantee (specimen attached at Annexure-B) issued by a scheduled bank in Pakistan, for an amount equivalent to 10% of the total value of the purchase order or as specified, in the letter of intent. The performance bond unless specified otherwise, shall remain valid till:

- 6.1.1 Completion of final satisfactory delivery in case of consumable items.
- 6.1.2 12-18 months from the date of satisfactory delivery of the equipment/machinery.
- 6.1.3 Satisfactory delivery/installation of system in case of the installation liabilities will be on supplier's part.
- 6.1.4 120 days in case of chemicals.

- 6.2 The Letter of Credit shall be operative upon receipt of Performance Bond (as specified in para 6.1) and integrity pact, any delay due to late submission of Performance Bond will be on supplier's account. Late submission of PBG should not affect the delivery schedule.

- 6.3 The performance bond shall be denominated in foreign currency or in currency of the contract/purchase order or in a freely convertible currency acceptable to the Company and shall be in the form of a bank guarantee.

- 6.4 In very special case subject to approval of the management, the P.B.G could be acceptable in Pak Rupee. However, an undertaking should be given by the supplier that in case of encashment of P.B.G. supplier shall deposit short fall amount due to Pak Rupee exchange rate.


6.5 Warranty/Guarantee:

In case where performance guarantee is not applicable, the supplier shall warrant that all goods supplied under the contract/purchase order are new, unused, of the most recent or current models and all recent improvements in design and goods have been incorporated, unless provided otherwise in the contract/purchase order. This guarantee shall remain valid for a period of twelve to eighteen months after the goods have been delivered or commissioned.

(Clause 16.2 to 16.8 of General Terms & Conditions are also applicable).

7. Delivery:

- 7.1 In case of "FOB" order/contract, shipment(s) shall be effected per vessel of Pakistan National Shipping Corporation (PNSC) owned or chartered vessels on "freight to collect" basis. Bill of lading to indicate "freight payable by the consignee at destination". In case goods ready for shipment and the PNSC vessel is



not available at port of loading, supplier shall intimate the same to Company immediately so that matter could be taken with PNSC in Pakistan.

7.2 In case of C&F order/contract, the supplier hereby guarantees/ensure:

- 7.2.1 To use clean and dry vessel suitable for marine transportation and shall not use tramp vessels.
 7.2.2 The goods/material will be shipped/dispatched with all care and diligence at their risk & cost and goods to be stored below deck. Accordingly, the supplier shall be responsible for all damages/losses during inland and marine transportation from the supplier's plant until arrival at Karachi port.
 7.2.3 To provide as part of its work all services and functions related to handling, loading, unloading, lashing and securing in ship's holds and all costs, charges and expenses of which shall be included in the purchase order/contract price, unless otherwise specified.

7.3 In case of FOB order/contract, the supplier's obligations shall be over after the goods have crossed the ship's rails. The co-ordination, scheduling and lining-up for a PNSC vessel shall be the obligation of the supplier.

7.4 The supplier shall reimburse the Company all additional duties, taxes and other such charges paid by the Company on account of short shipment by the supplier for all items subsequently shipped on a no-charge basis or otherwise by the supplier. The supplier shall also reimburse the Company all additional duties, taxes and other such charges paid by the Company on account of incorrect invoicing by the supplier.

7.5 Shipment shall be deemed to have been made when the supplier has shipped the goods against a clean bill of lading and all other such documentation, as specified in clause 9.3 & 9.4 appearing next in sequence) have been furnished to the Company.

7.6 The supplier shall ensure that all above mentioned acts and other incidental and ancillary functions are conducted in accordance with sound and acceptable engineering practices. The Company shall be entitled to oppose any incorrect or inadequate practice adopted by supplier in this respect and the supplier shall take corrective action/measure forthwith to correct such omissions. If any goods are discovered to be damaged or unacceptable at the point of loading, the supplier shall be responsible for replacement free of all charges and costs to the Company within the delivery period specified in the purchase order/contract.

8. Insurance:

8.1 All goods supplied under the purchase order/contract shall be fully insured in a freely convertible currency against loss or damage incidental to manufacture or acquisition, transportation, storage and delivery in the manner specified in delivery clause 7.

8.2 Marine Insurance shall be the responsibility of the Company unless otherwise specified.

8.3 The supplier shall advise the Company by fax at least seven days prior to the expected date of shipment, the following particulars:-

- 8.3.1 Name of the vessel and of the shipping company.
 8.3.2 Age of the vessel (which should be less than 20 years).
 8.3.3 Lloyds 100A1 or equivalent classification of the vessel.
 8.3.4 ETD from Port of dispatch and ETA at Karachi
 8.3.5 FOB/C&F value of the consignment.

The above information shall also be transmitted to the Company's underwriters at National Insurance Corporation by fax No. 0092-21-9202779 and to the Company referring Policy No. NIP/K/OP/002/73.

9. Payment:


9.1 Payment of FOB/C&F prices shall be made in the currency of bid through an irrevocable letter of credit (LC) established in favor of the supplier, negotiable through the bank of their choice. Bidders shall indicate full name and address of the negotiating bank and the place at which they wish to negotiate the letter of credit. All bank charges outside Pakistan will be on supplier's account and all bank charges within Pakistan will be at Company's account. If confirmed letter of credit is required then charges for confirmation will be on supplier's account.

9.2 The supplier's request (s) for payment shall be made to the Company in writing as follows:

9.2.1 It shall be accompanied by an invoice describing, as appropriate, the goods delivered and the services incurred and by shipping documents submitted pursuant to Clause 9.4 hereof and upon fulfillment of other obligations stipulated in purchase order/contract.

9.2.2 Against shipping documents on arrival of ordered material at consignee destination. Bidder (s) will have to clearly mention, if they wish to opt for this mode of payment

9.3 The letter of credit shall be available upon presenting the following documents to the negotiating bank within 15 days of the date of the bill of lading covering shipment of each consignment:



- 9.3.1- Invoice ----- 4 copies
 9.3.2- Packing list ----- 4 copies
 9.3.3- Bill of lading "freight to be paid by consignee at destination" evidencing shipment in terms of the purchase order to Karachi-Pakistan made copies out to order in the name of Co.'s bank, Notify party Sui Southern Gas Company Ltd., ----- 3 originals & 6 non-negotiable
 9.3.4- Certificate of Origin (Verified/ Endorsed by Chamber of Commerce) ----- 2 copies
 9.3.5- Manufacturers test certificate/ ----- 2copies Inspection report.

9.4 Without prejudice to the supplier's responsibility for providing documents mentioned as at 9.3.1 to 9.3.5 above to bank, the supplier shall forward the following non-negotiable documents directly to Company immediately after shipment so as to reach the Company at least 15 days prior to the arrival of the vessel at Karachi port.

- 9.4.1 -Invoice ----- 6 copies
 9.4.2 -Bill of Lading ----- 6 copies
 9.4.3 -Packing List ----- 6 copies
 9.4.4 -Certificate of Origin (Verified /Endorsed by Chamber of Commerce) ----- 2 copies*
 9.4.5 -Manufacturers Test Certificate/ ----- 2 copies
 Inspection Report.

9.4.6 The invoice to be exactly as per order/contract. Any deviation which render or cause the company to pay demurrage or any other charges with respect to clearance/handling etc. will be borne by the supplier.

9.5 No payment hereunder shall be deemed to be accepted by the Company of the goods covered by such payment nor release the supplier from responsibility thereof under the terms of the purchase order/contract.

9.6 If the Company is compelled to pay demurrage or storage charges or incurs any loss or suffers any damage at Karachi Port on account of non-compliance by the supplier of above requirements, the Company shall be entitled at their sole discretion to recover the same amount from supplier.

10. Termination of purchases order by supplier:

10.1 The supplier shall have the right to terminate the contract/purchase order if-

10.1.1 The Company fails to establish the letter of credit within the stipulated period as required under clause 9.1 hereof after the supplier has made compliance with the provisions of clause 6.

10.1.2 The Company becomes bankrupt or insolvent or makes an assignment for the benefit of its creditors.

10.1.3 The Company is in default and breach of its obligation and liabilities under the contract/purchase order.


11. Installation/Commissioning/Training:

If installation/commissioning and training is required, the charges will be paid in Pak Rupee and will be subject to deduction of all local duty and taxes (as applicable).

12. Vehicle (s) supplied by foreign manufacturer / principal:

12.1 In case of supply of any type of vehicle (s) / earth moving vehicle (s) by the foreign principal / manufacturer. After clearance of vehicle from the custom, the local agent of the foreign supplier / manufacturer / principal will be completely responsible to get the vehicle (s) registered through Excise Department Government of Sindh and provide Original Registration book / Original Registration Invoice / Tax payment receipt / other related documents & provide the vehicle (s) number plate (s) to SSGC. Registration fee will be reimbursed by SSGC subject to submission of Government of Sindh Excise Department receipt.

12.2 The bidder / supplier shall quote only those vehicle (s) / which fully comply to Pakistani environment and can operate in Pakistan. The bidder should ensure that vehicle (s) consumable i.e (fuel/oil & lubricant/spares) are easily available in Pakistan.



On Non Judicial Stamp Paper of Rs. 50/- (Fifty) Per 100,000
Format of Bid Bond Guarantee

BANK GUARANTEE NO.....
DATE OF ISSUE.....
DATE OF EXPIRY.....
AMOUNT.....

TE # SSGC/FP/_____

Sui Southern Gas Company Limited,
ST. 4/B, Block-14,
Jalshan-e-Iqbal,
Sir Shah Suleman Road,
Karachi.

Dear Sir,

Bid Bond Bank Guarantee


In consideration of M/s..... hereinafter called the Bidder
having submitted the accompanying bid & in consideration of value received from Bidder we hereby agree and
undertake as follows:

- To make unconditional payment of Rs..... upon your written demand without further recourse, question or reference to the Bidder or any other person in the event of withdrawal of the aforesaid bid by the Bidder before the end of the period specified in the bid after the opening of the same for the validity thereof or if no such period to be specified within 90 days (150 days in case of Single Stage Two Envelope bidding procedure) after said opening and or in the event that the Bidder shall within the period specified therefore or if no period specified within 15 days after the prescribed forms are presented to the Bidder for signature the Bidder shall fail to execute such further contractual documents if any, as may be required by the terms of the bid as accepted or on the Bidder failure to give the requisite Performance Bond as may be required for the fulfillment of resulting contract.
- To accept written intimation (s) from you as conclusive and sufficient evidence of the existence of a default of non-compliance as aforesaid on the part of Bidder and to make payment accordingly within 03 days of the receipt of the written intimation.
- No grant of time or other indulgence to, or composition or arrangement with the Bidder in respect of the aforesaid Bid with or without notice to us shall in any manner, discharge or otherwise, however affect this Guarantee and our liabilities & commitments hereunder.

This Guarantee shall be binding on us and our successors in interest and shall be irrevocable.

Ours faithfully,

(Stamp and signature of the issuing bank)



On Non Judicial Stamp Paper of Rs. 50/- (Fifty) Per 100,000
Format of Performance Bond Guarantee

BANK GUARANTEE NO.....
DATE OF ISSUE.....
DATE OF EXPIRY.....
AMOUNT.....

Sui Southern Gas Company Limited,
ST. 4/B, Block-14,
Gulshan-e-Iqbal,
Sir Shah Suleman Road,
Karachi.

TE # SSGC/FP/_____

Dear Sirs,


In The Sum of Rs..... Account.....
in Karachi under the Purchase

In consideration of your having placed Purchase Order No.....
dated..... On M/s..... called Supplier and in
consideration for value, received from Supplier, we hereby agree and undertake as under:

1. To make unconditional payments to you from time to time as called upon or make an unconditional payments Rs..... Being Ten Percent (10%), of the value of the Purchase Order price mentioned in the said Purchase Order, on your written demand(s) without further resource, question or reference to Supplier or any other person, in the event of default or non-performance and / or non-fulfillment by Supplier of his obligations liabilities & responsibilities under and in pursuance of the said Purchase Order of which you shall be the sole judge.
2. To accept written intimation from you as conclusive and sufficient evidence of the existence of a default or breach as aforesaid on the part of Supplier and to make payment accordingly within 3 (three) days of receipt thereof.
3. To keep this guarantee in full force from the date hereof as specified in General or Special terms & conditions.
4. That on grant of time or other indulgence to amendment in the terms of the purchase order by agreement with Supplier in respect of the Performance of his obligations under and in pursuance of the said Purchase Order with or without notice to us, shall in any manner discharge or otherwise, however, affect this Guarantee and our liabilities and commitments there under.
5. This Guarantee shall be binding on us and our successors in interest and shall be irrecoverable.
6. This Guarantee shall not be affected by any change in the constitution of the Guarantor Bank or the constitution of M/sthe Supplier.

Yours faithfully,

(stamp and signature of the issuing bank)



(Format of Declaration)

General Manager (Procurement)
Sui Southern Gas Company Limited,
ST. 4/B, Block-14, Gulshan-e-Iqbal,
Sir Shah Suleman Road, Karachi.
Dear Sir,

Declaration

(the Seller/Supplier) hereby declares its intention not to obtain or induce the procurement of any contract, right, interest, privilege or other obligation or benefit from Sui Southern Gas Company Limited or any administrative subdivision or agency thereof or any other entity owned or controlled by it (SSGC) through any corrupt business practice.

Without limiting the generality of the foregoing, (the Seller/Supplier) represents and warrants that it has fully declared the brokerage, commission, fees etc. paid or payable to anyone and not given or agreed to give and shall not to give or agree to give to anyone within or outside Pakistan either directly or indirectly through any natural or juridical person, including its affiliate, agent, associate, broker, consultant, director, promoter, shareholder, sponsor or subsidiary, any commission, gratification, bribe, finder's fee or kickback, whether described as consultation fee or otherwise, with the object of obtaining or inducing the procurement of a contract, right, interest, privilege or other obligation or benefit in whatsoever form from SSGC, except that which has been expressly declared pursuant hereto.

(The Seller/Supplier) certifies that it has made and will make full disclosure of all agreements and arrangements with all persons in respect of or related to the transaction with SSGC and has not taken any action or will not take any action to circumvent the above declaration, representation or warranty.

(The Seller/Supplier) accepts full responsibility and strict liability for making any false declaration, not making full disclosure, misrepresenting facts or taking any action likely to defeat the purpose of this declaration, representation or warranty. It agrees that any contract, right, interest, privilege or other obligation or benefit obtained or procured as aforesaid shall, without prejudice to any other rights and remedies available to SSGC under any law, contract or other instrument, be voidable at the option of SSGC.


Notwithstanding any rights and remedies exercised by SSGC in this regard, (The Seller/Supplier) agree to indemnify SSGC for any loss or damage incurred by it on account of its corrupt business practices and further pay compensation to SSGC in an amount equivalent to ten times the sum of any commission, gratification, bribe, finder's fee or kickback given by (The Seller/Supplier) as aforesaid for the purpose of obtaining or inducing the procurement of any contract, right, interest, privilege or other obligation or benefit in whatsoever form from SSGC.

Yours faithfully,

Signature & Stamp (The seller/supplier)

Note:

1. The above declaration is required to be submitted by the Successful Bidder after issuance of Purchase Order (PO) or Letter of Intent (LOI) on Bidder's letter head, for purchase order / letter of intent of a total value of Rs. 10,000,000/- (Ten million) or above.
2. Please note that submitting the declaration is a mandatory requirement.



Tender Enquiry No. SSGC/FP/_____

Special Conditions of Tender Document

Note: In case of any conflict between Special Conditions of Tender Document and any other terms & conditions, the Special Conditions of Tender Document will govern / prevail.

1. Warranty / Guarantee Coverage

- i) The successful bidder / supplier guarantee that the goods supplied against above tender enquiry are in all respect in accordance with the tender specifications & Purchase Order and that material used are in accordance with the latest approved standards and are of good workmanship / quality. Any item or part of item if found to be substandard or not meeting the specified criteria as per pre-shipment / post shipment inspection report, than in such as event the Supplier / Bidder hereby warrants and undertake to replace the same on Duty Delivery Paid (DDP) basis (INCOTERMS 2010) i.e. free of all cost including but not limited to transportation, taxes and levies. In case successful bidder / supplier failure to replace the defective item /remove the defect(s) free of cost within the period specified by the Purchaser, the successful bidder / supplier will refund the relevant cost including all other expenses incurred by the purchaser in this regard.
- ii) The successful bidder / supplier must confirm that the warranty for non-consumable items will remain valid for 18 months and for consumable items (i.e. Chemical, Battery etc.) will remain valid for 6 Months after the goods have been successfully delivered or commissioned.
- iii) It is mandatory that the successful bidder / supplier will submit the attached undertaking at Annexure-11, duly filled, signed & stamped.
- iv) In case where performance bond guarantee is not applicable, the supplier shall confirm that all supplied goods under the contract / purchase order are new, unused, of most recent or current models and incorporate all recent improvements in design and goods unless and otherwise provided in the contract / purchase order.
- v) The Warranty Undertaking being provided by the local agent of the successful bidder (Principal) is required to be submitted at least on Rs.200/- Non-judicial stamp paper and should be duly notarized / attested. In the event when this Warranty Undertaking is being submitted by the principal who is overseas resident in that case the same would required to be notarized by the notary public and duly attested by the Pakistan Embassy or High Commission in that particular jurisdiction. Needless, to mention that in both cases the Warranty Undertaking will be executed by the duly authorized representative of the local agent or the principal, as the case may be.

2. Bid Security:

- a) Bid bond submission (2%) of the bid amount as mentioned in the clause 1.1 & 2 of Additional Terms for tender on F.O.B/C&F basis & 9 of General Terms & Conditions to be treated as null & void, however, other contents of clause 1.1 & 2 of Additional Terms for tender on F.O.B/C&F basis & 9 of General Terms & Conditions will remain unchanged. The submission of fixed amount of Bid security is appearing in the Price Schedule/BoQ.
- b) All the bidders are advised to furnish fixed bid security (Original instrument) as per amount in Pak Rs. Or US\$ appearing in price schedule/BOQ failing which their bid will be rejected.
- c) In case the bidder submit bid in the currency other than Pak Rs. Or US\$ their bid bond shall be equivalent after the conversion to the amount of fixed bid bond given in Pak Rs. Or US\$ mentioned in Price Schedule/BOQ. The exchange rate (issued by the Treasury Management Group of the National Bank of Pakistan or the State Bank of Pakistan selling rate) prevailing at the time of bid opening date will be applicable.
- d) The submission of fixed amount of bid security is also mandatory for all the bids valuing Rs.500,000/- or less.
- e) The word lowest bidder or the lowest evaluated bid has been substituted to read as **most advantageous bid**.
- e) Sub-clause 9.2 of the General Terms & Conditions to be treated as null & void, however other contents of clause 9 will remain unchanged.

3- Method For Submission of Bid Bond(Under Single Stage Two Envelope Bidding Procedure):

In case of Single Stage Two Envelope Tenders the fixed bid bond as per clause#09 of General Terms & Conditions and Clause# 02 of Additional Terms for tenders on FOB/ C&F basis to be placed in the Technical Proposal. However, if the bid bond is placed in the Financial proposal will also be considered. Without submission of bid bond(either in Technical proposal or Financial proposal) the bid will be rejected.

4. Bid Validity:

All offers shall remain valid up to 120 days from the date of opening of bids and bid bond shall remain valid for 150 days.

5. Evaluation Criteria and Comparison of Bids

In accordance with SRO 827 (1) / 2001 bidders tendering for Engineering goods produced in Pakistan and those Engineering goods specified in CGO-11 and amendments thereof by the Central Board of Revenue or Engineering Development Board. The successful bidder shall be accorded a Price preference in rupees up to a specific percentage (in proportion to the value addition) of the lowest quoted landed cost of an item of foreign origin with similar specifications as mentioned in the tenders




- i) Provided that:-
- The saving in foreign exchange is not less than the amount of price preference;
 - It is ensured that, in each case of such preference, the total import requirements for producing the supplies tendered for locally manufactured items has been duly indicated by the bidders.
- ii) Price preference shall be allowed as under:-
- Having minimum of twenty percent value addition through indigenous manufacturing, price preference shall be fifteen percent;
 - Having over twenty percent and up to thirty percent value addition through indigenous manufacturing, price preference shall be twenty percent, and
 - Having over thirty percent value addition through indigenous manufacturing, price preference shall be twenty five percent.
- iii) For the above purpose, we will require a complete breakdown of ex-factory price for goods manufactured in Pakistan. Any offer not accompanied with this cost breakdown will not be allowed to receive the above price preference.
- iv) Benefit of SRO 827 (1)/2001 shall be accorded to only those local manufacturers who are engaged in the manufacturing of goods specified in CG0 - 11 of 2007 or its latest version or as certified by the EDB. However in case of offer on FOB basis, the landed cost to be determined in accordance with the following criteria be taken for evaluation in case of International bidders, and shall be taken for the purpose of comparison with the price quoted by local manufacturers, who shall also be accorded the price preference in terms of SRO 827 (1)/2001. The landed cost determined in accordance with the afore said criteria shall be taken for bid evaluation in case of international bidders, and shall be taken for the purpose of comparison with the price quoted by the local manufacturers. Example of landed cost for evaluation of the international bidders is given here under:

EXAMPLE

S. No.	Cost Components for computing landing cost of imported Engineering goods in terms of SRO 827 (1)/2001 in Pak Rupees.
i.	FOB Value.
ii.	Sea Freight (Actual quoted by the bidder on the basis of PNSC rates, which shall be announced by the bidder at the time of opening of the bid).
iii.	C&F value (i + ii). (CFR value).
iv.	Insurance @ 1% of C&F Value given at iii above.
v.	CIF value (iii + iv).
vi.	Handling Charges @ 1 % of CIF Value given at v above.
vii.	Import Value (v + vi) for the purposes of levying Customs Duty.
viii.	Customs Duty at applicable rate, which shall be calculated on the import value given at vii above.
ix.	Duty Paid Value.
x.	Sales Tax at applicable rate, which shall be calculated on the duty paid value given at ix above.
xi.	Duty & Sales Tax paid value (ix + x).
xii.	Withholding Tax at applicable rate, which shall be calculated on duty & sales tax paid value given at xi above.
xiii.	LC Charge@ 0.25% of FOB Value given at i above.
xiv.	Clearing Charges @ 0.25% of C&F Value given at iii above.
xv.	SED at applicable rate, Which shall be calculated on the import value given at vii above to be taken as nil as it stands withdrawn.
xvi.	Provincial Infrastructure Cess (at applicable rate) on %age of import value given at vii
xvii.	KPT Wharfage @ Rs.140 per cubic meter or the prevailing rate.
xviii.	Craneage Loading & Other Charges@ 0.25% of C&F Value given at iii above.
xix.	Inland Transportation Charges from Port to Coating Factory (From Port of final destination in case of products other than pipes, where coating is not required).
xx.	Cost of imported engineering goods (xi to xix).
xxi.	LESS: Handling Charges taken at Sr. No. vi (Notional Value taken for calculating assessed value for purpose of calculating custom duty, sales tax and withholding tax by the customs authority).
xxii.	LESS: Sales tax taken at x above. (Adjustable as output tax).
xxiii.	LESS: With Holding Tax. (Adjustable against final assessed tax).
xxiv.	Total deductions (xxi + xxii + xxiii)
xxv.	Net cost of imported engineering goods (xx minus xxiv)

- v) Foreign bidders are essentially required to submit letter of PNSC for ocean freight transportation rate for break bulk/hedges from their local agent.
- vi) Please indicate approximate shipping specification, i.e. weight and measurements of the packages/bundles and also total gross weight (in terms of metric tons), and total gross volume (in terms of cubic meters) of each consignment separately.
- vii) For evaluation of bids customs duty, taxes and all other charges prevailing on the date of public opening of bids will be used, where applicable.
- viii) For the purpose of price comparison and evaluation of bids, financial charges will also be added to arrive at a landed cost, which will inter-alia include, mark up and L/C opening charges etc.



- ix) If the local manufacturer becomes the lowest evaluated bidder after Price Preference, order will be placed at the price (landed Cost) quoted by the lowest evaluated international bidder. In case the local bidder does not accede to the request of SSGCL for best negotiated rates at par with those received from International bidder for particular item(s) then, the order will be placed on the lowest evaluated international bidder.
- x) "Price Preference" shall not be in "Value Terms" it should only be for the sake of reference for comparison purposes (local & foreign bids).
- xi) Bank details shall be mentioned by the bidders for the purpose of opening LC/ Payment.
6. **Declaration / Integrity Pact / Certification:**
it is required to be submitted by the Successful Bidder on their letter heads after issuance of Purchase Order (PO) or Letter of intent (LOI) for the value of Rs.10,000,000/- (Ten Million) or above in case of local bidder and US\$ 100,000 & above in case of foreign bidder.
Submission of the declaration as at ANNEXURE-C is a mandatory requirement for successful bidder.
7. **Third Party Pre-Shipment Inspection Criteria / Scope of Work as given in the Tender Documents will be followed at the time of Third Party Inspection, which will be carried out by SSGC nominated Third Party Inspection Firm in case the order value exceeds US\$100,000 except screwed pipe fitting tenders.**
8. **"The successful Bidder shall provide the revenue stamps and copy of challan, of value at the rate of twenty Five (25) paisa per every Hundred Rupees or part thereof of the amount of the purchase order, or at the prevailing rate as specified by the Government of Province of Sindh." Further as per Government of Sindh Board of Revenue notification NO.CIS/SWB/BOR/LET-17/2022-808 dated 08-06-2022 all judicial and non-judicial stamp paper of the denomination of rupee five hundred and above shall be exclusively on e-stamp.**
9. **Bank Guarantee (Bid Bond/Guarantee/Performance Bank Guarantee) will be made on Non-Judicial stamp paper at the prevailing rate as specified by the respective Provinces. Further the bidder/contractor submitting the Bid Bond guarantee/Performance Bond/Guarantee being prepared by the State Bank's schedule banks should ensure that there should be no deletion/insertion/alteration/modification of any terms in the Bid Bond/PBG guarantee format as given in the tender document or else bid will be liable for rejection.**
10. **"Original counter slip of token which is issued with original tender document to be attached on the TOP of envelope at the time of bid submission."**
11. **Cancellation of Purchase Order**
In case the supplier fails to deliver the material within the specified delivery schedule as given in Purchase order (P.O.) and maximum upto 120 days after the expiry of the specified delivery schedule as per Purchase Order, the Purchase Order will be treated automatically as cancelled at supplier's sole risk & cost. However, for the sake of clarity liquidated damages (Clause-27 of General Terms Conditions) and Default by Supplier (Clause-28 of General Terms Conditions) will be treated as given in the General Terms & Conditions of the tender documents.
12. **Correct Postal Address**
Bidders are essentially required to provide correct and latest postal, e-mail & web addresses, phone/cell/fax numbers at the time of purchase of tender documents for effective and timely communication, failing which in event of any non-delivery of information / communication the procuring agency will be considered as non-responsive.
13. In case the local agent requires to offer bid from more than one principal / Manufacturer, it is mandatory to purchase separate tender document for each principal / Manufacturer, failing which the bid submitted with the original tender document will only be accepted and the bid with photocopy of tender document will be rejected.
14. **Blacklisting Mechanism of Suppliers and Contractors and their Local Agent:**
Black listing mechanism is attached separately in the tender documents which will become an integral part of Tender Documents and now be followed / enforced in true letter & spirit and supersede the Black listing terms as mentioned in the General Terms & Conditions.
15. *The Successful Contractor(s) / Supplier(s) / Consultant(s) shall submit a copy of Professional Tax Certificate with their Invoices / Bills failing which the payment will not be released.*
16. **Authentications of Performa Invoice / Authority Letter and other documents by the Principal / Manufacturer:**
The Authentication of Authority Letter and Performa Invoice will be obtained from the Principal / Manufacturer as and when required. If the authentication not received within the stipulated time frame the bid will be liable for rejection and the Bid Bond / Earnest Money will be encashed.
17. **Bid Bond & PBG (Performance Bank Guarantee) for Proprietary Tenders**
In case of proprietary Tenders, the Bid Bond & Performance Bank Guarantee (PBG) are not required / Applicable.
18. *Any Bidder who change / amend the BOQ / Price Schedule (description / Bid Form, Quantity, UOM etc.) will render the bid as conditional bid and will be liable for rejection.*
19. *Delivery Schedule will commence after the opening of Letter of Credit (LC). In case the bidder does not submit the performance bond as specified, the delivery time of goods shall be deemed to have commenced 10 days (15 days in case of import) from the issuance of letter of intent / purchase order. The proceeds of the performance bond shall be payable to the Company as compensation for any loss resulting from the supplier's failure to complete its work under the purchase order / contract.*



20. In the event of release of Performance Bank Gurante (PBG) after its encashment, the amount of the PBG to be released will be converted in Pak Rupees at the exchange rate prevailing at the time of encashment. The amount so converted will be released in Pak Rupee (PKR) to the foreign bidder or to their local agent duly authorized by the foreign principal.
21. SSGC will not pay invoices if they are turned in after 6 months of work completion / material delivered.
22. As per FBR Regulations Ref# C.No.4 (24) IT- Budget/2021-142150-R, Dated: 23rd September, 2021 to make the payment online. Therefore, all the local manufacturers are required to provide their only one Bank Account number (IBAN number) on the 'FORM-X' attached duly signed & stamped as one time information, which shall be firm (not changeable) for all the future payment transactions.
23. It is mandatory for the bidders to follow all the terms and conditions given in the tender documents without any addition / deletion / amendment and submit the bid accordingly. Therefore, in this context, the bidders are requested not to give their own terms and conditions as it tantamount towards the conditional bid. Otherwise their terms and conditions will not be considered and the Purchase Order / Contract will be awarded based on only as per SSGC tender terms and conditions.

24. **Payment:**

The supplier after delivery of goods and its acceptance shall submit invoice to Finance Department of the Company, containing following information i.e:

(a) Purchase order No. & date	(b) Items	(c) Quantity	(d) Price	(e) Invoice value
(f) Point of delivery	(g) Delivery challan indicating delivery date, etc.			
(h) Supplier(s) are required to submit signed and stamp acknowledgement slip, Sales Tax return, Annex "C" & Annex "I" (whichever applicable) in which Sales Tax (of relevant Sales Tax invoice) is paid.				

Payment will be made within 30 days of completion of stated requirements.

25. **Joint Ventures:**

In the event that the bidder is bidding as a Joint Venture, the Company will require the joint venture agreement duly executed by the parties to the Joint Venture to be submitted with the bid. The joint venture parties shall also furnish an undertaking to be jointly and severally liable for all liabilities arising out of obligation under the Purchase Order / Contract. The Joint Venture agreement of the parties must specify share of each partner and name of the lead partner along with their registration with the FBR, SST and BST and in case of failure to specify these two narrations the joint venture agreement will not be entertained.

26. In case the insurance policy submitted by the contractor is expired during the execution of job, it is the responsibility of the user department to coordinate with the contractor to get it renewed/updated till the period the job is completed/commissioned.

In case the job is not completed within the given time as per tender terms and the insurance policy submitted by the contractor expires, the contractor is liable to get this insurance policy renewed / updated immediately till the period of the job is completed / commissioned as per tender terms failing which the contractor will be responsible for any loss to SSGC.

27. Bidders can quote their rates on both i.e. Price Schedule as well as Bill of Quantity (BoQ).

28. Company reserve the right to award the Purchase Order /LOI to the most advantageous bidder.

29. As per SRO 592(I)/2022 of PPRA Regulations, for Procurement Contracts/Purchase Orders worth of Rs. 50 million and above, bidders/contractors are required to submit the Beneficial Owner's Information for Public Procurement Contracts/Purchase Orders (Annexure-I).

30. In case quoted item(s) falls under SRO No. 604 (see attachment) i.e. Solar Power System, Module/Cells and allied accessories/parts/spares etc. - then in that case supplier is responsible to fully comply stated SRO and to arrange, provide and bear all associated costs for all necessary test reports, certificates, pre-shipment inspection reports, other documents etc. (as mentioned in SRO). Further, Pre-shipment Inspection should be from approved companies as mentioned in Appendix H of Import Policy Order (see attachment).

31. **Fixed Bid Security – Alternative Bid**

A bidder cannot submit two bids/offers with a single fixed bid security/pay order. However, the alternative bids/offers with separate fixed bid security/pay order can be accepted, failing which the bids will be liable for rejection. In case the bidder quote different make/brands/model that will also be considered as an Alternative bid/offer and require to submit separate Bid bond for each make/brand/model.

32. Bidder will be blacklisted and henceforth cross debarred for participating in respective category of Public Procurement proceedings for a period of (not more than) six months, if fail to abide with a bid securing declaration (which is an integral part of tender document), however, without indulging in corrupt and fraudulent practices, if in breach of obligation(s) under the Bid conditions:

a) The bidder have withdrawn or modified their bid during the period of bid validity as specified in the tender terms.



- b) Having been notified of the acceptance of bid by procuring agency during the period of bid validity (i) failure to sign the contract or accept purchase order (ii) fail or refuse to furnish the performance security or to comply with any other condition as mentioned in the tender document.
33. Wherever the "Rate Only" is mentioned (either on BOQ or anywhere in tender documents) the same shall only be applicable not exceeding 15% of the original procurement for the same items as given in the BOQ for package basis. In case the requirement is on item wise basis (not package basis) then not exceeding 15% of the original Procurement for the same items (on item wise basis) as given in the BOQ.
34. **Lots:** In case when the tender is floated on LOT basis, following clauses to be applied:
- a) The bidder(s) are essentially / mandatorily required to submit fixed bid bond as mentioned in the bid form/BOQ/Invitation to Bid. Separate fixed bid bond to be submitted against each individual LOT and its validity to be 150 days at the time of opening of technical proposal.
- b) Evaluation for each LOT will be carried out separately. Each LOT will be awarded separately.
35. For open competitive bidding if the most advantageous bidder is new local manufacturer, 10% trial order will be placed and remaining 90% order will be awarded to the next most advantageous bidder at their own quoted rates.
36. Subsequent to issuance of Purchase Order/LOI, successful bidder has to submit 10% Performance Bank Guarantee of the Purchase Order/LOI value unless & until specified in the Tender Documents. Clause# 16.1.5 mentioned in General Terms & Conditions to be treated as null & void.
37. Where the Pre-shipment inspection is applicable and in case of partial shipment is required by the bidder the cost of the 1st Pre-shipment inspection will be borne by SSGC, whereas, cost of the 3rd Party inspection for the remaining shipment(s) will be borne by the bidder/manufacturer.
38. Purchase order value mentioned in clause # 6 of sub-clause # 6.1 (Performance Bond) of Additional Terms for Tenders on FOB/C&F basis (Section-6) to be read as US \$ 10,000 instead of US \$ 25000. However, other contents of clause & sub-clauses of 6 (Performance Bond) of Additional Terms for tender on F.O.B/C&F basis will remain unchanged.
39. Redressal of Grievances And Settlement of Disputes
- Any bidder feeling aggrieved by any act of the procuring agency after the submission of his bid may lodge a written complaint concerning his grievances within seven days of announcement of the technical evaluation report and five days after issuance of final evaluation report.
 - In case, the complaint is filed against the technical evaluation report, the GRC shall suspend the procurement proceedings.
 - In case, the complaint is filed after the issuance of final evaluation report, the complainant cannot raise any objection on technical evaluation of the report. Provided that the complainant may raise the objection on any part of the final evaluation report in case where single stage single envelope bidding procedure is adopted.
40. The sub clauses 33.2, 33.4 & 33.5 of clause 33 of General Terms & Conditions to be treated as null & void.
41. All the bidders are allowed to participate in the subject procurement without regard to nationality/origin, except bidders of some nationality/origin, prohibited in accordance with policy of the Federal Government. Following countries are ineligible to participate in the procurement process:
- India
 - Israel
42. In Open Competitive Bidding Procedure where the quoted price is less than Rs. 500,000/- the Bid Bond will be retained in lieu of PBG.
43. In case the Bid Bond is not required, the bidder must submit the Form of Bid-Securing Declaration attached with the Tender Document else the Bid will be liable for rejection.
44. All Tenders floated through EPADS are to be governed by S.R.O. 296(I)/2023 dated: March 8, 2023 "E-Pak-Procurement Regulations 2023". In case of any conflict between SSGC Tender Terms / Instructions to Bidders and the PPRA EPADS Rules, the S.R.O. 296(I)/2023 will prevail.

45. Samples:



When sample submission is required. Suppliers/bidders must submit samples:

- a) Along with the bid, if stated in the tender documents.
- b) Within the time specified in the tender.
- c) Upon request from the User Department for technical evaluation through official email/ letters.

SAMPLE SUBMISSION LOCATION/ DEPARTMENT:


All samples must be submitted to the Procurement Department - Tender Room, SSGC Head Office with Duly filled in form "Y" attached in the tender document. Samples submitted other than the Procurement Department - Tender Room, SSGC Head Office will not be considered/accepted.

The supplier/bidder must:

- Fill in all required details (e.g., Tender No., Bidder Name, and Sample Description).
- Attach supporting documents (if required).
- Submit the completed Form-Y along with the sample.

In absence of any of the above stated requirements the Samples will not be considered/accepted.

NOT FOR BIDDING PURPOSE




Declaration of Ultimate Beneficial Owners Information for Public Procurement Contracts.

1. Name
2. Father's Name/Spouse's Name
3. CNIC / NICOP/Passport No.
4. Nationality
5. Residential address
6. Email address
7. Date on which shareholding, control or interest acquired in the business.
8. In case of indirect shareholding, control or interest being exercised through intermediary companies, firms or other legal persons or legal arrangements in the chain of ownership or control, following additional particulars to be provided:

1	2	3	4	5	6	7	8	9	10
Name	Legal form (Company/Limited Liability Partnership /Association of Persons/Single Member Company/Partnership Firm/Trusted/Any other Individual, Body Corporate (to be Specified))	Date of Incorporation / Registration	Name of Registering Authority	Business Address	Country	Email Address	Percentage of shareholding control or interest of BO in the Legal Person or Legal Arrangement	Percentage of shareholding, Control or Interest of Legal Person or Legal Arrangement in the Company	Identity of Natural Person who Ultimately owns or Controls the Legal Person or Arrangement

9. Information about the Board of Directors (details shall be provided regarding number of shares in the capital of the company as set opposite respective names).



ANNEXURE - II

WARRANTY UNDERTAKING

M/s. Sui Southern Gas Co. Ltd.
SSGC House, Sir Shah Qureshi Road,
Gulshan-E-Iqbal, Karachi.


From _____ (FIRM NAME)

Tender Enquiry No. _____ Date _____

1. In case we stand as the lowest bidder and the order is placed on us against the cited tender enquiry, we hereby guarantee that the goods supplied against above tender enquiry are in all respect in accordance with the tender specifications and the material used are in accordance with the latest approved standards and are of good workmanship and quality. Any item or part of item if found to be substandard or not meeting the specified criteria after pre-shipment / post shipment inspection report, than in such an event the Supplier hereby warrants and undertake to replace the same on DDP basis (INCOTERMS 2010) i.e. free of all cost including but not limited to transportation, taxes and levies.
2. In case of our failure to replace the defective item / remove the defect(s) free of cost within the period specified by the Purchaser, we will refund the relevant cost including all other expenses incurred by the purchaser in this regard.
3. This warranty will remain valid for 18 months after the goods have been successfully delivered or commissioned.

Signature _____

Company Stamp _____



Supplier code: _____

FORM-X

Bank account details form for all Beneficiaries

(Mandatory requirement for Digital Online Banking)

As per FBR Regulations ref # C.No.4 (24) IT-Budget/2021-142150-R dated 23rd Sept'2021 to make the payment online w.e.f. 01-11-2021. All beneficiaries are required to fill in the below details, which is mandatory:

Name of Firm: _____

Address of Firm: _____

CNIC #: _____

NTN #: _____

Bank Name: _____

Bank A/C Title name: _____

Branch code: _____

Bank A/c #: _____

(16 Digits)

Bank IBAN #: _____

(9 Digits)

Information already submitted.

Note: Please be attached copy of Cheque / Account Maintenance Certificate (Mandatory)



Authorized Sign & Stamp

Date: _____

Note: All payments transactions will be made on above mentioned Account details. This is only a one time information to be provided by the all beneficiaries. Incase if the above detail has already submitted, please tick the box above "Information already submitted" and also ensure Form-X is duly signed & stamped.




FORM "Y"
(SSGC – sample submission form)

SECTION A: BIDDER INFORMATION	
FIELD	DETAILS
Bidder Name / Firm Name	
NTN / GST No.	
Address	
Contact Person	
Contact Number	
Email Address	
Declaration by Bidder	
I/We hereby declare that the sample(s) submitted are in accordance with the tender specifications and terms. I/We understand that failure to submit correct and complete samples may lead to disqualification.	
Signature of Bidder:	

SECTION B: TENDER DETAILS	
FIELD	DETAILS
Tender No.	
Tender Opening Date	
Item(s) for which sample is submitted	
Quantity of Sample Submitted	
Specification/Description of Sample	
Make:	
Brand:	
Serial No:	
Generics: size, height, weight, width:	
Other description:	

SECTION C: FOR OFFICE USE ONLY (TO BE FILLED BY TENDER ROOM)	
FIELD	DETAILS
Date & Time of Submission	
Received By (Tender Room Staff Name & Sign)	
Tender Room Stamp	
Remarks (if any)	



JR

Form of Bid-Securing Declaration

[The Bidder shall fill in this Form in accordance with the instructions indicated.]

Date: [date (as day, month and year)]

No.: [number of Bidding process]

Alternative No.: [insert identification No if this is a Bid for an alternative]

To: [complete name of Procuring Agency]

We, the undersigned, declare that

We understand that, according to your conditions, Bids must be supported by a Bid-Securing Declaration.

We accept that we will be blacklisted and henceforth cross debarred for participating in respective category of public procurement proceedings for a period of (not more than) six months, if fail to bid with a bid securing declaration, however without indulging in corrupt and fraudulent practices, if we are in breach of our obligation(s) under the Bid conditions, because we

- (a) have withdrawn our Bid during the period of Bid validity specified in the Letter of Bid; or
- (b) having been notified of the acceptance of our Bid by the Procuring Agency during the period of Bid validity; (i) fail to sign the Contract; or (ii) fail to furnish the Performance Security (or guarantee), if required, in accordance with the ITB.

We understand this Bid Securing Declaration shall terminate if we are not the successful Bidder, upon the earlier of (i) our receipt of your notification to us of the name of the successful Bidder; or (ii) twenty-eight days after the expiration of our Bid.

Name of the Bidder: _____

Name of the person duly authorized to sign the Bid on behalf of the Bidder: _____

Title of the person signing the Bid: _____


Signature of the person named above: _____

Date signed: _____

*: In the case of the Bid submitted by joint venture specify the name of the Joint Venture as Bidder

**: Person signing the Bid shall have the power of attorney given by the Bidder attached to the Bid

[Note: In case of a Joint Venture, the Bid-Securing Declaration must be in the name of all members to the Joint Venture that submits the Bid.]



PRICE SCHEDULE FOR GOODS TO BE OFFERED OUTSIDE PAKISTAN

TENDER ENQUIRY NO : SSGC/FP/ 14306

Section-3

Sr. No	Description	Country of Origin / Make / Brand	Qty	Unit	Unit FOB price Port of Loading	Total FOB Cost / Item (COL 4x6)	Unit Price C&F (Port of Entry Karachi)	Total C&F Port of Entry (COL 4x8)	* Only for local manufacturer	
									Unit FOR Price	Total FOR Price (COL 4x10)
1	2	3	4	5	6	7	8	9	10	11
	<u>SWING CHECK VALVES</u>									
1	[1] 53658783 VALVE SWING CHECK 6" NB FLANGE END,ANSI CLASS 600,RTJ,(AS PER SPECS.)		2	Each						
	<u>FULL BORE BALL VALVES - GEAR OPERATED</u>									
2	[2] 05224643 VALVE BALL 8" FLANGED ENDS RTJ CLASS 600, WITH (MANUAL) GEAR OPERATOR(AS PER SPECS.)		11	Each						
	<u>SWING CHECK VALVES</u>									
3	[3] 53658753 VALVE SWING CHECK 2" FLANGED ENDS RTJ CLASS 600(AS PER SPECS.)		4	Each						
	<u>PLUG VALVES - WRENCH OPERATED</u>									
4	[4] 53641613 VALVE PLUG 2",ANSI CLASS 600, FLANGED ENDS RTJ,REGULAR PATTERN WITH WRENCH(AS PER SPECS.)		3	Each						
	<u>PLUG VALVES - GEAR OPERATED</u>									
5	[5] 53652123 VALVE PLUG 8" , FLANGED ENDS ANSI CLASS 600, RTJ, REGULAR PATTERN, WITH MANUAL (GEAR) OPERATOR (AS PER SPECS. ATTACHED)		4	Each						
	<u>FULL BORE BALL VALVES - GEAR OPERATED</u>									
6	[6] 05224663 VALVE BALL 12" FLANGED ENDS RTJ,ANSI CLASS 600, WITH MANUAL (GEAR) OPERATOR(AS PER SPECS.)		3	Each						
	<u>BALL VALVES</u>									
7	[7] 05224533 VALVE BALL 2" FLANGED ENDS ANSI,RTJ,CLASS 600, GRADE 'B' FULL BORE, WRENCH OPERATED(AS PER SPECS. ATTACHED)		6	Each						
	<u>FULL BORE BALL VALVES - GEAR OPERATED</u>									
8	[8] 05224623 VALVE BALL 6" DIA FLANGED ENDS CLASS 600 RTJ GEAR OPERATED(AS PER SPECS.)		3	Each						
	<u>FULL BORE BALL VALVES - GEAR OPERATED</u>									
9	[9] 05224653 VALVE BALL 10" FLANGED ENDS RTJ CLASS 600, WITH MANUAL (GEAR) OPERATOR(AS PER SPECS.)		4	Each						
	<u>SWING CHECK VALVES</u>									
10	[10] 53658793 VALVE SWING CHECK 8"DIA, FLANGED ENDS RTJ, ANSI CLASS 600		2	Each						
	<u>FULL BORE BALL VALVE - GEAR OPERATED</u>									
11	[11] 05224753 VALVE BALL 8" FULL BORE, WELD ENDS ANSI CLASS 600,SUITABLE FOR PIPE I.D 7.625" IN API 5L GRADE-B COMPLETE WITH ACTUATOR AND REMOTE CONTROL.(AS PER SPECS.)		1	Each						
	<u>NEEDLE VALVES FCS BODY</u>									
12	[12] 53740313 VALVE NEEDLE 1/2" API 3000 LBS RATING END THREADED FEMALE WITH HAND WHEEL OPERATOR (AS PER SPECS. ATTACHED)		6	Each						
	<u>PLUG VALVES</u>									
13	[13] 53646063 PLUG VALVES IN SIZE 1" DIA, API 3000 LBS RATING,END THREADED FEMALE,WRENCH OPERATED COMPLETE WITH WRENCH (AS PER SPECIFICATIONS ATTACHED)		15	Each						

Delivery Schedule: Complete shipment is required within 20 to 24 weeks (or earlier) from the date of issuance of L/C.



PRICE SCHEDULE FOR GOODS TO BE OFFERED OUTSIDE PAKISTAN

TENDER ENQUIRY NO : SSGC/FP/ 14306

Section-3

Sr. No	Description	Country of Origin / Make / Brand	Qty	Unit	Unit FOB price Port of Loading	Total FOB Cost / Item (COL 4x6)	Unit Price C&F (Port of Entry Karachi)	Total C&F Port of Entry (COL 4x8)	* Only for local manufacturer	
									Unit FOR Price	Total FOR Price (COL 4x10)
1	2									

Delivery Schedule: Complete shipment is required within 20 to 24 weeks (or earlier) from the date of issuance of L/C.
FIXED BID SECURITY USD 1,270 OR PKR 360,000

NOTE TO SUPPLIER: * According to SRO827(1)2001, "engineering goods" means good specified in CGO11/2007, as per SRO the bidder will be considered as local manufacturer for the engineering goods if their names are appearing in the CGO list.

IMPORTANT

We draw your special attention to :


- Prices given here in shall take into account with relevant factors including discounts , if any.
- Proforma Invoice of the principal is mandatory required to be submitted by the Supplier which shall match with the price schedule.
- In case when bidder submit alternate bids a separate bid bond for each bid is required. otherwise bid will be liable for rejection.
- All offer shall remain valid up to 120 days from the date of opening of bids and bid bond shall remain valid for 150 days.
- The prices on FOB and C&F (PNSC freight to be submitted by the bidder(s) is mandatory) basis should be quoted separately as given above.
- Following information shall be mentioned in the bid.
(a) Country of Origin (b) Port of Shipment (c) Estimated Gross weight / Volume
- The bid validity and the delivery schedule shall match with the schedule of Requirement / Bid Form. In all circumstances the bid validity and delivery schedule given on Schedule of Requirement / Bid Form will prevail without any further recourse.
- Any Bidder who change/amend the Price Schedule (Description, Quantity, UOM etc.) will render the bid as conditional bid and will be liable for rejection.

Signature : _____

Person Name : _____

Company's Name : _____

Date : _____



S T A M P

End of page, any entry beyond this line would be invalid





SSGC SUI SOUTHERN GAS COMPANY LIMITED STATEMENT OF REQUIREMENTS

REF. NO:			
DATE	24	02	2026

DEPARTMENT: Planning & Development

DESCRIPTION OF JOB / PROJECT: 8" dia x 9Km for receiving Patheji form POD Sujawal


JOB / PROJECT EXPECTED DATE OF COMMENCEMENT: Feb, 2026

JOB NUMBER: 51260001

SCHEDULE & PLACE OF DELIVERY: Khadeji Store

TYPE OF STOCK: Region Tendering

SR. NO:	DESCRIPTION OF MATERIAL REQUIRED	INDEX NO:	UOM	QUANTITY
Assorted Valves				
Ball Valves				
01	Full Bore Ball Valves in size 12" dia, ANSI Class 600, Flange Ends to RTJ and complete with Manual (Gear) operator.	05-22-466-3	Nos	03
02	Full Bore, Ball Valves in size 10" dia, ANSI Class 600, Flange Ends to RTJ and complete with Manual (Gear) operator.	05-22-465-3	Nos	04
03	Full Bore Ball Valves in size 8" dia, ANSI Class 600, Flange Ends to RTJ and complete with Manual (Gear) operator.	05-22-464-3	Nos	11
04	Full Bore, Ball Valves in size 8" dia, ANSI Class 600, Welding Ends suitable for pipe I.D 7.625" in API 5L X70 and complete with Actuator & Remote Control.	05-22-475-3	Nos	01
05	Full Bore Ball Valves in size 6" dia, ANSI Class 600, Flange Ends to RTJ and complete with Manual (Gear) operator.	05-22-462-3	Nos	03
06	Ball Valves in size 2" Flange end to RTJ, ANSI Class 600, wrench operated (complete with wrench)	05-22-453-3	Nos	06
Plug Valves				
01	Plug Valves in size 8", ANSI Class 600, Regular Pattern, Flanged Ends to RTJ complete with manual (Gear) operator.	53-65-212-3	Nos	04
	Plug Valves in size 2", ANSI Class 600, Regular Pattern, Flanged Ends to RTJ complete with manual (Gear) operator.	53-64-161-3	Nos	03
03	Plug Valves in size 1", API 3000 lbs. Rating, End threaded Female, wrench operated (complete with wrench).	53-64-606-3	Nos	15
Swing Check Valves				
01	Swing Check Valves in Size 8", Flange Ends to RTJ, ANSI Class 600.	53-65-879-3	Nos	02



NOT FOR BIDDING PURPOSE

Handwritten signature

02	Swing Check Valves in Size 6", Flange Ends to RTJ ANSI Class 600.	53-65-878-3	Nos	02
03	Swing Check Valves in Size 2", Flange Ends to RTJ, ANSI Class 600.	53-65-875-3	Nos	04
NEEDLE VALVES				
01	Needle Valves in size 1/2", API 3000 lbs. Rating, End threaded Female and complete with Hand Wheel Operator.	53-74-031-3	Nos	06

NOT FOR BIDDING PURPOSE

12

FAIZ

INDEPENDENT
FAIZ AHMED
Dy. Chief Manager
(Projects)-P&D
Sui Southern Gas Co. Ltd.

Shamim Hyder

SHAMIM HYDER
Act. General Manager (P&D)
HEAD OF DEPARTMENT
Sui Southern Gas Co. Ltd.

Q. Anwar 9/3/26

APPROVAL OF DIVISION HEAD
(WITH STAMP)

DELIVERY SCHEDULE :


Annexure -II

The above quantity of Assorted Valves are to be shipped in accordance with the following delivery schedule

<u>Shipment</u>	<u>Goods</u>	<u>Arrival date Karachi Port (for C&F contracts)</u>	<u>FOB/FOR Delivery</u>
1	As per schedule of Requirement (Annexure-I)	24 Weeks from the date of opening of Letter of Credit	20 weeks from the date of opening of Letter of Credit

Engr. **AATIR SALMAN**
Dy. General Manager
P & D - Transmission
Sui Southern Gas Co. Ltd.

Shamim Hyder
SHAMIM HYDER
Act. General Manager (P&D)
Sui Southern Gas Co. Ltd.



NOT FOR BIDDING PURPOSE



SUI SOUTHERN GAS COMPANY LIMITED (SSGC)

NOT FOR BIDDING PURPOSE

TECHNICAL SPECIFICATION FOR ASSORTED VALVES

RECEIVED
02 FEB 2024
ASGM (T) Office-KT

RECEIVED
07 FEB 2024
DGM HC OFFICE
HSE & QA

RECEIVED ASGM (TS)
23 JAN 2024
1061
Sui Southern Gas Co. Ltd.

RECEIVED
08 JAN 2024
ASGM (T) Office-KT





TABLE OF CONTENTS

1 GENERAL 3

2 ABBREVIATIONS/SYMBOLS 4

3 CODES, REGULATIONS AND STANDARDS 4

4 GENERAL REQUIREMENTS 5

5 MANDATORY REQUIREMENTS 8

6 SPECIFICATIONS FOR VALVES 9

7 MANUAL OPERATORS FOR THE VALVES 14

8 VALVES ACTUATORS 15

9 INSPECTION AND TESTING REQUIREMENTS 19

10 EXTERNAL SURFACE TREATMENT 24

11 MARKING 24


12 DOCUMENTS 25

13 LUBRICANT 27

14 INSPECTION CERTIFICATES 27

15 PACKING 27

NOT FOR BIDDING PURPOSE



Reviewed By	Atique Ur Rehman AE (R&D Transmission) 	Mehboob Ali Manager (Transmission)
Approved By	A/SGM (TS) 	A/SGM (Transmission)

date



1 GENERAL

1.1 Scope

1.1.1 The purpose of this specification is to describe the minimum functional and technical requirements for Assorted Valves suitable for natural gas transportation.

1.1.2 The specification also covers the design, fabrication, and shipment of manual gear operators and actuators to be supplied with these valves in natural gas service.

1.1.3 This specification is to be applied in conjunction with the Schedule of Requirements (SOR) and the supporting procurement Data Sheet (where applicable).

1.2 Definitions

PURCHASER means OWNER and MANUFACTURER means CONTRACTOR/SUPPLIER/BIDDER. This definition shall apply throughout this specification.

1.3 Errors or Omissions

1.3.1 Any errors or omissions noted by the Manufacturer in this Specification shall be immediately brought to the attention of the Purchaser.

1.4 Deviations

1.4.1 All deviations to this Specification shall be brought to the knowledge of the Purchaser in the bid. All deviations made during the procurement, design, manufacturing, testing and inspection shall be with written approval of the Purchaser prior to execution of the work. Such deviations shall be shown in the documentation prepared by the Manufacturer.

1.5 Conflicting Requirements

1.5.1 In the event of conflict, inconsistency or ambiguity between the contract's scope of work, this Specification, and National Codes & Standards referenced in this Specification, the Purchaser shall be consulted and a ruling, in writing, shall be obtained before any work is started.

1.5.2 Some requirements in this specification may be modified by specific requirements in the Schedule of Requirements. In case of conflict, the specific requirements supersede this specification.

Reviewed By	Atique Ur Rehman AE (P&D-Transmission) 	Mehboob Ali, Manager (Transmission)
Approved By	A/SGM (TS) 	A/SGM (Transmission)





2 ABBREVIATIONS/SYMBOLS

For the purpose of this document, the words and expressions listed below shall have the meanings assigned to them as follows:

ABBREVIATION	NAME
ANSI	American National Standard Institute
API	American Petroleum Institute
ASME	American Society of Mechanical Engineers
ASTM	American Society of Testing and Materials
BC	Bolted Cover
BW	Butt Welding
CS	Carbon Steel
D	Diameter
Gr.	Grade
Max	Maximum
MTC	Material Test Certificate
SOR	Schedule of Requirements


3 CODES, REGULATIONS AND STANDARDS

Manufacturer shall meet or exceed the requirements of the latest edition of the following applicable codes, regulations and standards, except as superseded herein.

- ASME B31.8, Gas Transmission and Distribution Piping Systems
- ASME Section VIII, Div - 1, Pressure Vessels
- ASME Section IX, Qualification Standard for Welding and Brazing Procedures, Welders, Brazers and Welding and Brazing Operators
- ASME Section V, Non-Destructive Examination
- ASME B1.20.1, Pipe Threads, General Purpose (Inch)

Reviewed By	Atique Ur Rehman AE (P&D Transmission)	Mehboob Ali Manager (Transmission)
Approved By	A/SGM (TS)	A/SGM (Transmission)


date:





- ASME B16.5, Steel Pipe Flanges and Flanged Fittings
- ASME B16.47, Large Diameter Steel Flanges (NPS 26 through NPS 60)
- ASME B16.20, Metallic Gaskets for Pipe Flanges - Ring Joint, Spiral Wound
- ASME B16.21, Nonmetallic Flat Gaskets for Pipe Flanges
- ASME B16.25, Butt-welding Ends
- ASME B16.9, Wrought Steel Butt-Welding Fittings
- ASME B16.10, Face-to-Face and End-to-End Dimensions of Valves
- ASME B16.11, Steel Socket Weld Fittings
- ASME B16.34, Valves - Flanged, Threaded and Welding End
- ASME B40.100, Pressure Gauges and Gauge Attachments
- API 600, Steel Gate Valves - Flanged and Butt-welding ends
- API 602, Compact Steel Gate Valves - Flanged, Threaded Welding & extended-body ends
- API 594 Check Valves - Wafer and Wafer-Jug, and double flanged type
- API 6D, Specification for Pipeline Valves (Gate, Plug, Ball and Check valves)
- API 6FA, Specification for fire test for Valves
- API 607, Fire Test for soft seated quarter-turn valves
- API 6FD, Specification for Fire Test for Check Valves
- API 598, Valve Inspection and Testing
- BS 1868, Steel Check valves (Flanged and butt-welding ends)
- BS 1873, Steel Globe and Globe stop & Check valves (Flanged & Butt-welding ends)
- BS 5351, Steel Ball valves
- BS 5352, Steel wedge Gate, Globe and Check valves (200mm and smaller)
- BS 6755, Testing of valves Part 1: Production pressure testing requirements
- BS 6755, Testing of valves Part 2: Specification for Fire type testing requirements
- ASTM Standards, as applicable
- Bolt Torquing/Tensioning procedure for Flanged connection
- MSS SP 25, Standard Marking System for Valves, Fittings, and Unions
- MSS SP 44, Steel Pipeline Flanges
- MSS SP 55, Quality Standard for Steel Castings for Valves, Flanges and Fittings and Other Piping Components
- MSS SP 91, Guidelines for Manual Operation of Valves

Reviewed By:	Atique Ur Rehman AE (P&D Transmission) 	Mehboob Ali Manager (Transmission)
Approved By:	A/SGM (TS) 	A/SGM (Transmission)






4 GENERAL REQUIREMENTS

- 4.1 This specification covers various types of valves intended for use in the natural gas service with design rating as specified in the Schedule of Requirements and temperature between -10°C and +75°C.
- 4.2 This specification incorporates the supplementary specification of manual operators and actuators for valves. The valves and operators shall be compatible. The manual operators/actuators shall be included in the scope of supply by the manufacturer wherever specific operator types are specified.
- 4.3 The manufacturer shall be responsible for the design, manufacture, inspection, operability and fitness for service of the valves and operators supplied under this specification. Dimensions for all the valves shall conform to the standard dimensions for such valves given in API Specification 6D (latest edition) for Pipeline Valves.
- 4.4 All ball valves shall be of fire safe design conforming to API 607 (latest edition).
- 4.5 All plug valves and check valves shall be of fire safe design conforming to API 6FA & API 6ED (latest edition).
- 4.6 Fire test certificates, Fire test Reports with drawing of the Valve under Fire Test and photographs of Fire test event requirement as specified in the standards, are required to be submitted with the bid. Fire Safe Certification shall include Fire Safe Tests on at least one valve of each model and shall be submitted with the bid documents. Valves qualified by fire safe tests shall be proven in the natural gas service for a period of at least three (03) years following the date of the test. All above documents must be signed and stamped by third party inspection firm/inspector who witness the fire safe test of valves as a proof of verification. Failure to provide above documents shall be liable for rejection of bid documents.
- 4.7 API Certificate
- 4.7.1 Bidders/Manufacturers are required to submit certified copy of valid API 6D accreditation certificates for the specific valve type with the bid with date of initial accreditation
- 4.7.2 Each valve which would be manufactured according to API Standard must have API monogram on valve body
- 4.8 Original Technical Literature
The Bidder shall submit with his bid, detailed printed technical literature (in original) giving a description of the valve design and mode of operation, the materials used for

Reviewed By	Atique Ur Rehman AE (P&D Transmission)	Mehboob Ali Manager (Transmission)
Approved By	A/SGM (TS)	A/SGM (Transmission)

date





each valve and each operator quoted to this specification. Bids not in conformity to this requirement are liable for rejection. Each valve and each operator shall be fit for all year service on site.

4.9 Sales Track Records

4.9.1 The Bidder shall submit the supporting documents of sales track record for the offered assorted valves, including copies of purchase order & satisfactory certificate of operations of five (5) different end users related to Oil & Gas Sector with similar requirement along with their email (email address of end user's company domain and not the commercial domain like Yahoo, Gmail, or Hotmail, etc.), fax, telephone, address and name of persons to contact to whom they have supplied the offered assorted valves within the last five (05) years and have been successfully installed and operated.

4.9.2 Simply submitting a list of customers to whom the manufacturer has been supplying the offered assorted valves will not meet the intent and purpose of this requirement. Failure to comply with this requirement may result in rejection of the bid.

4.10 The Bidder and the Supplier covered by this Specification shall provide the following particulars of the equipment quoted or ordered:

- Make, type or series
- Pressure class
- Nominal diameter, bore/port area
- Types of ends (flanged or welding or threaded)
- Full details of materials
- Type of coating (above ground service)
- Manufacturer's Mark

4.11 Before manufacturing any valve under this Specification, the supplier shall supply to the Purchaser the drawings and a detailed description of the material, fabrication methods and testing procedures applicable to the valve to be manufactured.

4.12 The documents related to the fabrication of the valve shall be reviewed by the Purchaser. The said review however shall in no way relieve the Supplier from any responsibilities and liabilities in connection with the Goods ordered, their safe & reliable operation and the specified delivery date.

4.13 The manual operator wherever specified in this specification is an integral part of the valve and, as such, shall be installed and tested before delivery of the valve. Where no specific manufacturer or type is specified, the manufacturer shall select a suitable type.

Reviewed By	Ayiqe Ur Rehman AE (P&D Transmission) 	Mehboob Ali Manager (Transmission)
Approved By	A/SGM (TS) 	A/SGM (Transmission)





The manufacturer shall test all functions of the valve and the operating equipment.


- 4.14 Inspection and Testing shall be carried out by the manufacturer at the manufacturing plant. All valves shall be visually examined for conformity to Purchaser's specifications and tested under the applicable codes and standards to make sure they conform to their intended use.
- 4.15 The Purchaser shall have the right to witness or require 3rd party inspection service at any time during the fabrication, testing and shipment of valves supplied in accordance with these specifications and to verify compliance with the Terms and conditions of the contract and Terms of references (TOR) attached with the bid document.
- 4.16 The Supplier shall give due and proper notice of commencements of valve fabrication and test under these specifications to the Purchaser/Third party inspector appointed by SSGC.
- 4.17 The Purchaser reserves the right to increase, decrease and delete the quantity of all the items given herein the Schedule of Requirements.

5 MANDATORY REQUIREMENTS

- 5.1 Bids are invited directly from the manufacturer or their authorized local agents in Pakistan. Beside local agent, principle involvement would be acceptable as regional Sales Representative, if applicable. However, in any case, bids from stockiest and Brokers will be rejected.
- 5.2 The local agents/suppliers are required to submit valid authorization letter from the manufacturer failing which will make bid non-compliant.
- 5.3 The bidder shall provide a clear and concise, clause by clause, compliance or exception (with detail) commentary to these technical specifications duly signed and stamped on each page by Manufacturer which is mandatory for technical evaluation failing to submit this document may be considered non responsive.
- 5.4 Each valve, manual operator and actuator shall comply with the requirements of this specification. Valve, manual operator and actuator which do not strictly comply with the requirements of this specification are liable for rejection. However, if there is any deviation with the specification for the offered item, The bidder may submit the deviation sheet covering details of respective clause and bidder's offer against the clause. Acceptance of such deviation does not guarantee of approval and this would depend on discretion of Purchaser.

Reviewed By	Atique Ur Rehman AE (P&D Transmission)	Mehboob Ali Manager (Transmission)
Approved By	A/SGM (TS)	A/SGM (Transmission)

duh





6 SPECIFICATIONS FOR VALVES

6.1 Valve Design:

6.1.1 Each valve shall be supplied with beveled butt welding ends or flanged ends or threaded ends or socket weld ends or a combination thereof as specified in the description of valve under Schedule of Requirements. The chemical composition of the weld ends shall meet the following requirements:

Maximum Carbon contents	0.23%
Maximum Silicon contents	0.40%
Maximum Manganese contents	1.50%

Carbon equivalent: 0.43% Max by ladle analysis.

6.1.2 The internal diameter shall not vary more than 1/16 inch between the valve and the line pipe. The beveling ends shall be beveled at an angle of 30° ± 5° - 0° from the perpendicular to the axis of the valve with a root face of 1/16 inch ± 1/32 inch.

6.1.3 Where flanged valves are specified, facing will be as specified in the description of valves under Schedule of Requirements.

6.1.4 If welding end of valves are specified, the welding ends shall have dimensions and strength properties equivalent to those of the line pipe in accordance with Figure I-4 or I-5 of ASME B 31.8, Appendix-I.

6.1.5 Welding ends shall be free from defects such as laminations which could impair the quality of the welds for a distance of not less than 1" from the bevel. Compliance with this provision shall be assured by appropriate tests.

6.1.6 Each valve shall be supplied with lubricant, fit for service on site. The lubricant shall resist dissolving, gumming or chemical change in service. Sealing shall be resistant to aromatic hydrocarbons.

6.1.7 Each valve shall be designed in such a way that any failure of the operator will not affect any other part of the valve and the malfunction of the operating equipment shall be limited to these parts and any such defective component may be replaced without removing the valve from service.

6.1.8 Each valve including manual operator shall be fit for upright and horizontal installation.

6.1.9 Lugs shall be welded to the body of each valve with a nominal diameter exceeding 10" for handling and lifting equipment, transportation and installation.

6.1.10 All valves shall have position indicators, indicating, open, partially open and closed positions.

Reviewed By:	Atique Ur Rehman AE (P&D Transmission) 	Mehboob Ali Manager (Transmission)
Approved By	A/SGM (TS) 	A/SGM (Transmission)





6.1.11 Valves shall be fitted with manufacturer standard support ribs/legs, unless otherwise specified in the Schedule of Requirements.

6.1.12 The design of all valves shall ensure correct functioning and a tight shut off, even though the gas may contain dust, impurities, water or condensate. Valves shall be able to withstand a sporadic passage of water and/or Methanol (e.g. in the case of hydrostatic testing).

6.1.13 Valves shall be of the anti-static and anti-blow out stem type.

6.1.14 Valves shall not have bolted connections perpendicular to the centre line of the valve, i.e., such valves shall be fully welded. The final weld seam of fully welded valves shall be made in such a way that defects in the root are prevented.

6.2 Specific Valve Design

6.2.1 The following section gives valve design requirements specific to the valve type. Bidders/Manufacturers shall comply with these specific requirements.

6.2.1.1 Plug Valves

6.2.1.1.1 Plug valves under this specification shall be of lubricated type with venturi or regular pattern as indicated in the description of valve under Schedule of Requirements. The valve shall be filled with lubricant and complete with combination lubricator.

6.2.1.1.2 Plug valves under this specification shall have inverted taper plug with provision for adjustment of plug with respect to seat equalizer ring between plug and operating stem.

6.2.1.1.3 Plug valves shall have fire safe graphite stem packing and an arrangement for stem packing feed unit.

6.2.1.1.4 Plug valves shall have side feed seat sealant injection provision.

6.2.1.1.5 Plug valves under this specification shall be of pressure balance type.


6.2.1.1.6 The port area of regular plug valves shall be at least 60 percent and venturi type plug valve shall be at least 40 percent of the cross sectional area of the corresponding adjacent pipe internal diameter.

6.2.1.1.7 Plugs of all valves shall be case hardened and lapped with the valve body seat after ground finish. The plug surface shall be PTFE treated or ENP (Electro less nickel plated). ENP to be minimum of 35 microns.

6.2.1.1.8 All plug valves shall be provided with weather seals for both stem and cover to

Reviewed By	Atique Ur Rehman AE (P&D Transmission) 	Mehboob Ali Manager (Transmission)
Approved By	A/SGM (TS) 	A/SGM (Transmission)

date





prevent corrosion.

6.2.1.2 Ball Valves

6.2.1.2.1 Each ball valve shall be designed and constructed for pigging.

6.2.1.2.2 Each valve shall be of the double-block-and-bleed type with double piston effect or as specified in the SOR (Schedule of Requirement).

6.2.1.2.3 Each valve shall be designed and constructed so as to minimize the entrapment of fluid in the valve body. A bleed assembly for the removal of entrapped liquids shall be provided on each side of each valve.

6.2.1.2.4 Each ball valve shall be provided with secondary seals between the ball and the seats. Secondary sealing may for example be by lubrication (in which case re-lubrication shall be feasible) or by another sealing system. Seals shall be resistant to aromatic hydrocarbons, methanol, etc.

6.2.1.2.5 Ball valves seat arrangement should be Primary Metal Seat and Secondary Soft Seat (PMSS) preferably in sales gas services or as specified in the SOR. The bidder is required to provide details of seat arrangement. Seat material should be compatible with the composition of gas.

6.2.1.2.6 The seal between ball and seat ring shall have a secondary sealing system e.g. using a lubricant, with facilities for re-lubrication during operation. The lubricant shall not solidify, dissolve or undergo chemical change at operating temperatures from -10°C to +75°C.

6.2.1.2.7 Connections to valve bodies shall be welded or threaded connections. Welded connections shall not be used for connections to valve bodies. The pressure sensing lines connections shall be provided directly on the valve bodies. Pressure sensing lines shall have isolating valves installed. These isolating valves shall be welding end for the ends towards the valve body (if applicable).

6.2.1.2.8 Drain connections shall be installed at the lowest point of each valve; however, these shall be positioned such that access is not prevented when the valve is mounted on a foundation plate or support while installed horizontally.

6.2.1.2.9 Pressure relief connections shall be located in the upper quarter of each valve. The diameter (D) of pressure relief lines shall be 1/2" for less than 4" dia valve and at least 1" for 4" dia valves and above.

6.2.1.2.10 Ball shall be ENP (Electro less nickel plated) and shall be stress relieved ENP to be a minimum of 75 microns.

Reviewed By:	Atique Ur Rehman AE (P&D Transmission) 	Mehboob Ali Manager (Transmission)
Approved By	A/SGM (TS) 	A/SGM (Transmission)

date





6.2.1.2.11 An external pressure relief valve with an isolating valve may be installed to prevent cavity over-pressurization.

6.2.1.3 Check Valves:

6.2.1.3.1 Check valves under this specification shall conform to API 6D (Latest Edition).

6.2.1.3.2 The valves shall have leakage free bolted cover (BC).

6.2.1.3.3 The check valve shall be of swing check type.

6.2.1.4 Needle Valves:

6.2.1.4.1 The valve shall have its application in pressure gauge installation, bubble-tight shutoff of natural gas required.

6.2.1.4.2 The size shall be as per the Schedule of Requirements.

6.2.1.4.3 The pressure/temperature rating shall be as per the Schedule of Requirements.

6.2.1.4.4 Bonnet locking stainless steel pin to prevent accidental removal.

6.2.1.4.5 The valve shall be globe pattern or compact design with ends screwed female NPTF, wheel operated or "T" bar handle operated as specified in the Schedule of Requirements, and 3000 psig cold working pressure.

6.2.1.4.6 Precision-machined stem shall have rolled stem threads. The end of the stem shall be needle pointed. Below stem thread packing gland required.

6.2.1.4.7 Metal-to-Metal Seat. Hardened and ground seat centering, non-rotating tip.

6.2.1.5 Gate Valves

6.2.1.5.1 The required metal seated gate valves should be hand wheel operated with rising stem ideal for general service on gas applications.

6.2.1.5.2 The size of the valve shall be as per Schedule of Requirements.

6.2.1.5.3 The gate type shall be Slab Gate.

6.2.1.5.4 The stem type shall be Rising Stem.

6.2.1.5.5 The operating temperature shall be -10°C to +75°C.

6.2.1.5.6 The end connection shall be Flanged RTJ, ASME B16.5 with class as per Schedule of Requirements.

6.2.1.5.7 The valve design & testing standard shall be API Spec. 6D (Latest Edition).

6.2.1.5.8 The sealing surfaces of the gate and seat are hardfaced for wear and corrosion resistance.

6.2.1.5.9 Screwed ends should be NPTF ASME B16.10.

Reviewed By	Atique Ur Rehman AE (P&D Transmission) 	Mehboob Ali Manager (Transmission)
Approved By	A/SGM (TS) 	A/SGM (Transmission)





6.3 Valve Material

6.3.1 Where not explicitly specified, the valve material shall be as under:

6.3.1.1 The body of each valve shall be forged or cast from easily weldable low alloy killed carbon steel or as specified. The steel used for valves shall conform to the standards stated in API 6D or material standards equivalent to these.

6.3.1.2 Non-metallic parts and elements such as packing, seal, sealing, injectable material, sealants and lubricants as required and shall be suitable for the service intended for, and should conform to the requirements of API 6D.

6.3.2 Plug Valves

6.3.2.1 Plug material shall be low alloy cast steel material suitable for pressure vessel application, conforming to material standards stated in API 6D or materials equivalent to API 6D material standards.

6.3.3 Check Valves

6.3.3.1 The body material of check valves shall be in carbon steel (CS) conforming to ASTM A 216 WCB. The internal material is to be suitable for installation in off take horizontal lines in natural gas service.

6.3.3.2 The seat material in body and disc should be suitable for pressure and temperature class/rating specified.

6.3.4 Needle Valves

6.3.4.1 The body material of needle valves shall be forged Carbon Steel conforming to ASTM A105 Gr. II or Equivalent / ASTM A182F 316 Stainless Steel / ASTM A105 Forged Single Piece Steel Plated or Equivalent.

6.3.4.2 The bonnet material shall be ASTM A182F 316 Stainless Steel / ASTM A105 Forged Single Piece Steel Plated or Equivalent.

6.3.4.3 The stem material shall be 316 Stainless Steel.

6.3.5 Gate Valves

6.3.5.1 The handwheel material shall be Ductile Iron.

6.3.5.2 The body material shall be ASTM A216-WCB/A351-CF8/CF8M/CF3/CF3M/A105.

6.3.5.3 The bonnet shall be ASTM A216-WCB/A351-CF8/CF8M/CF3/CF3M/A105.

6.3.5.4 The bonnet gasket material shall be 304 Wound Grafoil.

6.3.5.5 The stem will be ASTM A182-F6a/A105+ENP/LE2+ENP/F304/F316/F304L/F316L.

6.3.5.6 The stem packing material shall be Braided Graphite or Die-formed Graphite Ring or

Reviewed By:	Atique Ur Rehman AE (R&D Transmission) 	Mehboob Ali Manager (Transmission)
Approved By:	A/SGM (TS) 	A/SGM (Transmission)





PTFE.

- 6.3.5.7 The yoke sleeve material shall be Ductile Ni-resist.
- 6.3.5.8 The grease nipple material shall be Stainless Steel.
- 6.3.5.9 The gland material shall be ASTM A 182 Gr. F6a.
- 6.3.5.10 The gate material shall be ASTM A105+ENP/LE2+ENP/F304/F316/F304L/F316L.
- 6.3.5.11 The studs material shall be A194 2H+A193 B7/ A1938+B8/A193 8M+A193 B8M.
- 6.3.5.12 The seat material shall be Metal to Metal (STL/SS304/SS316/SS304L/SS316L).

7. MANUAL OPERATORS FOR THE VALVES

7.1. General

Where required manual gear operators shall be supplied for use with valves in natural gas transmission lines with respective design rating to ANSI and design temperature of -10°C and +75°C. No stem extension is required except where specified in the Schedule of Requirement.

7.2. Technical Requirement

The following listed requirements shall be fulfilled by the manufacturer/supplier of the manual operators:

7.2.1.1 Compatibility between Valve and Manual Operator

The valve manufacturer shall be responsible for the correct dimensioning/sizing of the operator (Gear) and compliance with the requirements of this specification.


7.2.1.2 Torque for Manual Operation

7.2.1.2.1 The torque required to open a valve at a pressure drop across the valve equal to 100% of the maximum pressure rating of ANSI Class 600 (or as per schedule of requirement) shall be reasonable. The maximum driving torque shall be 250 Nm (Newton Meter). Each manual operator shall be designed to withstand a torque of 600 Nm. The breakaway torque and any upset condition shall be taken care of to establish the design torque. Each manual operator shall be of the self-releasing type.

7.2.1.2.2 The force required at the lever/wrench or the hand wheel to operate the valve shall not exceed 250 N (Newton).

7.2.1.2.3 In the bid, the Bidder shall indicate the minimum time and the number of rotations of the hand wheel required to open or close the valve.

Reviewed By	Atique Ur Rehman AE (P&D Transmission)	Mehboob Ali Manager (Transmission)
Approved By	A/SGM (TS)	A/SGM (Transmission)





- 7.2.1.2.4 The hand wheel shall be vertical and placed sidewise adjacent to the Valve.
- 7.2.1.2.5 The operator shall, after assembly be equipped with a position indicator and corresponding metallic plate bearing the inscription (in English) open/closed. Stops are to be provided at the fully opened and closed position.
- 7.2.1.2.6 Flange dimensions for operating equipment shall be in accordance with the hand wheel and suitable for later installation of pneumatic actuator where indicated.
- 7.2.1.3 Lubrication and Materials
The manual operator gearing and the bearings shall be lubricated with a suitable lubricant. Each gear-box shall be so designed that no lubricant can escape even under inadequate storage conditions. Cast iron shall not be used for any component of any manual operator with the sole exception of gear boxes.
- 7.2.1.4 Assembly of Valve and Manual Operator
 - 7.2.1.4.1 Each manually operated valve shall be assembled prior to shipment and shall be ready for installation upon delivery. Each valve shall be suitably protected from damage during transportation.
 - 7.2.1.4.2 Each manually operated valve shall be shipped in the open position. Hand wheel shall be removed and packed separately placed in the valve crate or attached to the valve skid. Valves in size less than 4 inches shall be wrench operated except otherwise specified in the Schedule of Requirement.
- 7.2.1.5 External Surface Treatment
Valve gear shall be delivered from the factory and blasted and coated or painted in accordance with the manufacturer's standard specifications.
- 7.2.1.6 Instructions
The Supplier shall provide the Purchaser with six copies of original installation and operating instructions manual (in the English language) for the operators upon delivery.

8. VALVES ACTUATORS

8.1 General

Where required Actuators shall be supplied pre-installed with valves for installation on main pipeline/valve assemblies, transporting high pressure natural gas. The Supplier shall be responsible for design, manufacture, inspection, operability and fitness for service of the actuators supplied under these specifications.

Reviewed By:	Atique Ur Rehman AE (P&D Transmission) 	Mehboob Ali Manager (Transmission)
Approved By:	A/SGM (TS) 	A/SGM (Transmission)





8.2 Technical Requirement

8.2.1 The following listed requirements shall be fulfilled by the manufacturer/supplier of the valve actuators:

8.2.1.1 Actuators shall be suitable for Local Valve operation, pneumatic i.e., gas over oil pressure.

8.2.1.2 Actuators shall be of a piston type utilizing gas supply for hydraulic operation (with automatic level equalizing of the gas/oil circulation system) converting pneumatic pressure into hydraulic pressure to operate the valves. Piston sleeves shall be designed for the full differential pressure to which they could be exposed. Provision for speed control shall be included.

8.2.1.3 Actuator where required shall be supplied as a single assembly with actuator and other accessories supplied pre-installed with the Valve.

8.2.1.4 Valve, actuators shall preferably be supplied from a same vendor/manufacturer; however if a valve is provided with an actuator from other source, but supplied as part of valve requisition, the responsibility of the overall valve assembly (valve complete with actuator and/or accessories) shall be with the Contractor.

8.2.1.5 The actuators shall be compatible to the valves and respective design rating to ANSI and temperature of -10°C to +75°C.

8.2.1.6 Actuators and all appurtenances shall be suitable for outdoor installation and ambient temperatures ranging from 5°C to 55°C and exposure to a hot, dry and dusty environment with occasional sand storms.

8.2.1.7 The Bidder shall select proper actuators for the valves and shall assume full responsibility for valve operation under various differential pressure conditions across the valve.


8.2.1.8 Pipeline natural gas shall be used for operation of the Actuators. Maximum and minimum operating pressures of the pipeline are 1300 psig and 150 psig respectively. Regulators, if required for a selected pressure conditions for operation of the actuators shall be included in the scope of supply.

8.2.1.9 Unless other stroking times are indicated in the Data Sheet (where applicable), Max. Opening Stroke Time of actuator shall be at least 30 Seconds and, Closing Stroke Time of actuator shall be 05 Seconds. However, Vendor/manufacturer may propose better stroking time as per their manufacturing standard.

8.2.1.10 The valve/actuator package shall be supplied complete in all respects, including limit

Reviewed By:	Atique.Ur.Rehman AE (P&D-Transmission) 	Mehboob>All Manager (Transmission)
Approved By	A/SGM (TS) 	A/SGM (Transmission)

Amir





- switches, solenoid valves, pilot valves, breathers, drains, explosion proof control cabinet, terminal boxes installed with terminal strips.
- 8.2.1.11 Limit switches, solenoid valves shall be pre-wired in terminal box for single point cable termination.
- 8.2.1.12 The control cabinet of the actuators shall be lockable and weather proof for all weather conditions. The limit switches and circuit blocks housings should be air tight and should not allow any moisture entrance.
- 8.2.1.13 All electrical equipment shall be certified for use in the intended area in accordance with the applicable standards from one of the following bodies:
- IEC International Electro-technical Commission
 - ATEX European Union Directive for Explosive Atmospheres
 - UL/FM Underwriters Laboratories / Factory Mutual
- 8.2.1.14 All electrical components of actuator/valve assembly shall be certified for use in Class-I, Div.-II, Group 2 or Zone-2 Gas Group IIA.
- 8.2.1.15 All instrumentation/control tubing shall be 316 stainless steel, and tubing fittings shall be 'Flareless Type' (or Ferrule type).
- 8.2.1.16 Electronic component including Solenoid valves and switches shall be 24 Volt DC power supply operable or other voltage level as specified in the Data Sheet (where applicable).
- 8.2.1.17 IP (Ingress Protection) of Electric Enclosures, IP requirement of actuator's various Enclosures i.e. JB's, Control panel and etc. shall be mentioned (shall meet ingress protection (IP) IP65 to IEC 60529 or NEMA 4X to NEMA 250 or equivalent.).
- 8.2.1.18 Provision shall be considered for open and closed position displays in Purchaser's central control room.
- 8.2.1.19 Electric Power Source Requirement shall be mentioned with the said source shall be built-in (integral part of actuator) or external (purchaser's purchaser's scope).
- 8.2.1.20 Considering the reliable and smooth operation of gas distribution/transmission system actuator mechanism shall preferably be SIL rated.
- 8.2.1.21 The valve actuator shall be designed so that the valve fails last position on loss of hydraulic/gas supply pressure, Control voltage deriving Solenoids, etc.
- 8.2.1.22 Bypass Operation Provision of Actuator shall be considered. Actuator shall be equipped with handwheel with interlocking mechanism for direct manual handling of valve.

Reviewed By:	Atique Ur Rehman AE (R&D Transmission)	Mehboob Ali Manager (Transmission)
Approved By:	A/SGM (TS)	A/SGM (Transmission)





- 8.2.1.23 Local Valve operation using hand pump shall be considered.
- 8.2.1.24 Where specified in the Data Sheet (where applicable) provision for Line Break Control System shall be considered to over-ride remote, local power operation, for installation on river crossing.
- 8.2.1.25 The Line Break Control System should operate with local sensing pressure as specified in the Data Sheet (where applicable) and sensitive to 7.5-10 psi per minute. Line break valve should be closed when a limit of rate of decrease of mainline pressure at the river crossing location reaches a minimum of 10 psi/minute or as specified in data sheet. Line break valve should be adjustable type with minimum range of 10 psi/min to 100 psi/min and vendor/bidder to specify its suitability. (Bidder shall clearly specify the suitability of the offered Line Break Control System for river crossing installation)
- 8.2.1.26 Pressure Controlled Emergency Shut-Down (ESD) control shall be considered at low gas pressure at the preset pressure range in case of line rupture. This ESD control feature will automatically activate in case of pressure drop during break or explosion of line and closes the valve.
- 8.2.1.27 Valve Local Position Indication Provision shall be considered, position box of actuator shall be equipped with local position indicator to observe the valve position locally either valve is open or close.
- 8.2.1.28 Tightness Tests of the completed actuator shall be made using air or inert gas at a test pressure of 1.1 times maximum allowable operating pressure. All joints in the piping should be soap tested at 50 and 100 psig.
- 8.2.1.29 All test functions of the complete valve including actuator shall be made at the manufacturer's premises and a test certificate submitted with the valves.
- 8.2.1.30 The valve/actuator unit shall have proper arrangements (i.e. Eye bolt for sling connection) to avoid any damage during installation/removal.
- 8.2.1.31 Actuator & accessories shall be fire resistant/fire proof and shall meet requirements of API 607. Certification shall be provided by the Vendor in this regard.
- 8.2.1.32 The actuator specified is in integral part of the package and, as such, shall be installed and tested before delivery of the valve. The supplier shall select an appropriate actuator for the required service.
- 8.2.1.33 The package shall be supplied completely assembled and factory tested at the specified set of conditions and shall be ready for installation.

Reviewed By	Atique Ur Rehman AE (P&D Transmission) 	Mehboob Ali Manager (Transmission)
Approved By	A/SGM (TS) 	A/SGM (Transmission)

Adhi





8.2.1.34 The Bidder shall submit together with his bid:

- a description of the design and mode of operation of actuators
- Electric wiring diagram of actuators
- P&ID diagram of the actuators
- GAD drawing with actuator assembled/mounted on the Valve

8.2.1.35 The bidder shall submit valid authorization certificate for use of U-Stamp for design and manufacture of the pressure containing cylinders and parts in accordance with the Pressure Vessel Code, ASME Section-VIII. The bidder shall confirm that hydraulic cylinders are ASME U Stamped.

8.2.1.36 Each actuator shall be fit for all year service on site.

9. INSPECTION AND TESTING REQUIREMENTS

9.1. General

9.1.1 The valves shall be inspected and tested for the following items as minimum requirement and in accordance with API 6D, API 598 and other applicable codes.

- Appearance Inspection (Workmanship)
- Visual Inspection
- Dimensional Inspection
- Welding and Non Destructive Testing
- Pressure Tests
- Functional / Operational Test with Operator installed
- Fugitive Emissions Test
- Antistatic Device Test
- Fire Safe Test Procedure and Criterion shall be in accordance with API 6FA, 6FD and 607 (whichever applicable)

9.1.2 The Purchaser's representative inspector shall have access to any part of the plant along with the area outside Manufacturer's plant which is responsible for fabrication of pressure containing parts of valves whenever work on the order is under way.

9.1.3 The valve manufacturer shall notify the Purchaser prior to the required tests, and any specified supplementary inspections or examinations, addressing the notice as stated in the purchase order or as mutually agreed with the Purchaser.

9.1.4 The valve stem shall be blow out proof and shall be statically grounded to the body.

Reviewed By:	Atique Ur Rehman AE (P&D Transmission)	Mehboob Ali Manager (Transmission)
Approved By:	A/SGM (TS)	A/SGM (Transmission)





9.2 Appearance Inspection (Workmanship)

9.2.1 Appearance inspection shall be done on all accessible surfaces of the valves.

9.2.2 Both inside and outside surfaces of casting material shall be free from harmful blowholes, fins, seizures or sand scales, sand inclusions and cracks and shall be in accordance with MSS-SP-55.

9.2.3 Machined surfaces shall be free from injurious defects in use and rust and finished condition shall be as per acceptable standards.

9.3 Visual Inspection

At a minimum, visual inspection of all pressure-containing and pressure-controlling steel forgings shall conform to ASME BPVC Section VIII, Division I, UF-45, and UF-46. Acceptance criteria shall be that no visible defects, including seams, laps, and folds, shall be accepted.

9.4 Dimensional Inspection

9.4.1 Dimensional inspection shall be done by using appropriate measuring instruments.

9.4.2 Dimensional inspection shall confirm the parallelism, rectangularity and face to face dimensions, bore diameter etc. All outline dimensions including actuators shall comply with the approved drawings.

9.5 Welding and Non Destructive Testing

9.5.1 Welding qualifications shall be as per ASME BPVC Part 5, ISO 15614.

9.5.2 All factory welds shall be made in accordance with the requirements of the American Welding Society and ASME Section VIII, Division I.


9.5.3 Procedure tests covering strength, hardness and toughness shall be made to show the fitness of the welding procedure used for factory welds shall be made by welders qualified in the procedure used, who have passed an appropriate welder qualification test. All welding operations shall be supervised by a qualified welding supervisor.

9.5.4 All welds shall be inspected visually by the welding supervisor. Welds, welding ends and any repair welds shall be tested by appropriate non-destructive methods to demonstrate to the welding supervisor that all welds, welding ends and repair welds meet the requirements of these specifications.

9.5.5 Without limitation of the generality of the foregoing, all welds parallel to the longitudinal axis of the valves, and 10% of all circumferential welds shall be inspected by radiographic methods. Each welding end shall be tested by dye penetration methods and each repair weld shall be tested by radiographic or ultrasonic methods. The welding

Reviewed By	Atique Ur Rehman AE (P&D Transmission) 	Mehboob Ali Manager (Transmission)
Approved By	A/SGM (TS) 	A/SGM (Transmission)

Handwritten mark





ends of valves shall be solidly sound and shall not be cause of failure in radiographic examination of the joints with piping.

9.5.6 Defects shall be removed, cleaned and prepared for inspection by magnetic particle or dye penetrant method to verify complete removal of the defect. Weld repair methods shall be in accordance with the approved welding procedures. All weld repairs to pressure containing parts shall be heat treated.

9.5.7 No weld in the body of any valve shall contain any lack of fusion. If feasible, body welds shall consist of both external and internal runs. Each weld shall be smooth and free from cracks. No weld shall contain any major inclusions. The height of the weld above the surface of the parent metal shall not exceed 1/8 inch. Undercuts shall not exceed 10% of the wall thickness or 3/64 inch, whichever is lower. Each welded joint shall be completely filled. No weld shall be thinner than the wall thickness of the parent metal.

9.5.8 Magnetic particle or dye penetrant techniques shall be employed to test:

- Pressure containing components smaller than 2 inch welded to other pressure components.
- Welds joining non pressure components such as lifting lugs to pressure components.
- Weld builds ups such as overhangs.

9.5.9 Radiographic, ultrasonic or both techniques shall be used for full volume inspection of:

- Pressure containing fabrication welds for 1/2 inch or larger components.
- Weld repair to these components.
- Major weld repairs to pressure containing components.

9.5.10 Valve bodies of welded construction shall be annealed if they include wall thickness of 1.20 inches or higher. All cast valve bodies, irrespective of wall thickness, shall be annealed. The annealing process shall be carried out after all repair welds, if any, have been completed.


9.6 Pressure Tests

9.6.1 Pressure tests shall be performed by the valve manufacturer at the valve manufacturer's plant or at a facility mutually agreeable to both the Manufacturer and Purchaser.

9.6.2 The equipment used to perform the required pressure tests shall not apply external forces that affect seat or body seal leakage.

9.6.3 Required protective coatings, such as paint, which can mask surface defects, shall not

Reviewed By	Atique Ur Rehman AE (P&E Transmission) 	Mehboob Ali Manager (Transmission)
Approved By	A/SGM (TS) 	A/SGM (Transmission)





be applied to any surface before inspection or pressure testing.

9.6.4 The pressure tests shall be performed on each valve in accordance with written procedures and applicability as mentioned in API 6D or API 598.

9.6.5 Hydrostatic Shell Test

9.6.5.1 Hydrostatic shell test of all valves shall be performed in accordance with Section 10.3 of API 6D.

9.6.5.2 The Hydrostatic Shell Test (including drain, vent and bypass lines) shall be made at the test pressure given in API 6D.

9.6.5.3 For double block and bleed valve, additional testing shall be done as per Annex L.9 of API 6D.

9.6.5.4 The duration of test pressure shall be as per Table 9 of API 6D.

9.6.5.5 Test pressures and hold times shall be continuously recorded on a test chart. Recorded test certificate and charts shall be submitted to the Purchaser.

9.6.5.6 The hydrostatic test fluid shall be water and shall contain a corrosion inhibitor.

9.6.5.7 There shall be no visible leakage permitted during the hydrostatic shell test.

9.6.6 Hydrostatic Seat Test

9.6.6.1 Hydrostatic seat test of all valves shall be performed in accordance with Section 10.4 of API 6D.

9.6.6.2 The Hydrostatic Seat Test shall be made at the test pressure given in API 6D.

9.6.6.3 For double block and bleed valve, additional testing shall be done as per Annex L.9 of API 6D.

9.6.6.4 The duration of test pressure shall be as per Table 10 of API 6D.

9.6.6.5 Test pressures and hold times shall be continuously recorded on a test chart. Recorded test certificate and charts shall be submitted to the Purchaser.

9.6.6.6 The hydrostatic test fluid shall be water and shall contain a corrosion inhibitor.

9.6.6.7 Seat leakage shall be monitored from the downstream side of the seat when under hydrostatic seat test.

9.6.6.8 Leakage criteria shall be as per Section 10.4.1 of API 6D.

9.6.6.9 For low pressure test, the testing medium shall be air or inert gas.

9.6.6.10 For ball valves, the low pressure seat test shall be conducted with the ball and seats dry and free of oil, grease or any lubricant.

Reviewed By	Atique Ur Rehman AE (P&O Transmission) 	Mehboob Ali Manager (Transmission)
Approved By	A/SGM (TS) 	A/SGM (Transmission)





9.6.7 Stem Backseat Test


- 9.6.7.1 Testing of backseat shall be performed as per Section 10.2 of API 6D.
- 9.6.7.2 The Backseat Test shall be made at the test pressure given in API 6D
- 9.6.7.3 The duration of test pressure shall be as per Table 8 of API 6D.
- 9.6.7.4 Test pressures and hold times shall be continuously recorded on a test chart. Recorded test certificate and charts shall be submitted to the Purchaser.

9.6.7.5 There shall be no leakage permitted for stem backseat test.

9.6.8 High-Pressure and Low-Pressure Closure Test:

- 9.6.8.1 When closure testing valves, the valve manufacturer's test procedure shall ensure that excessive force is not used to close the valve. The applied force may be determined from the appropriate figures mentioned in MSS SP-91 (Guidelines for Manual Operation of Valves).
- 9.6.8.2 The high and low pressure closure test shall be as per requirement mentioned in Table 1 of API 598.
- 9.6.8.3 Valves for which high pressure closure test is optional as mentioned in Table 1 of API 598 are still required to be able to pass the tests. The results shall be supplied if required by the Purchaser.
- 9.6.8.4 For high-pressure closure tests, the test fluid shall be air or inert gas. Unless otherwise specified in the purchase order, the test fluid temperature shall be within the range 5°C (41°F) to 38°C (100°F). For low pressure closure test, test fluid shall be air or inert gas.
- 9.6.8.5 Water used can contain water-soluble oil and a corrosion inhibitor. When specified by the Purchaser, a wetting agent shall be included in the water.
- 9.6.8.6 When air or gas is used for closure tests, the valve manufacturer shall be capable of demonstrating the adequacy of the method of leakage detection.
- 9.6.8.7 Closure test pressures shall be as per Table 3 of API 598.
- 9.6.8.8 For closure tests, the required test pressure shall be maintained for at least the minimum time specified in Table 4 of API 598.
- 9.6.8.9 For both the low-pressure closure test and the high-pressure closure test, visual evidence of leakage through the disc, behind the seat rings, or past the shaft seals is not permitted and structural damage is not permitted. The allowable rate for leakage of test fluid at the seat-sealing surface interface, for the duration of the tests shall

Reviewed By	Atique Ur Rehman AE (P&D, Transmission) 	Mehboob Ali Manager (Transmission)
Approved By	A/SGM (TS) 	A/SGM (Transmission)





be as per Table 5 of API 598.

9.6.8.10 The allowable leakage rate for closure tests of valves with nonmetallic seat materials shall be equal to that specified in Table 5 of API 598 for a metal-seated valve of equivalent size and type.

9.6.8.11 Closure test procedure shall be as per Section 6.4 and 6.5 of API 598.

9.6.8.12 For double block and bleed valve, the high-pressure closure test procedure shall be as per Section 6.6 of API 598.

9.7 Antistatic Device Test

When specified in the purchase order, antistatic testing shall be performed. The electrical resistance shall be tested with a power source not exceeding 12 V to have continuity between the parts listed in Section 5.8 of API 6D when tested on a dry valve before pressure testing.

9.8 Fugitive Emissions Test

9.8.1 When specified in the purchase order, for natural gas transmission service, valves shall undergo fugitive emission qualification testing. This shall be performed in conformance to a national or international standard such as:

- API 624 for rising stem valves
- API 641 for quarter-turn valves
- ISO 15848-1 for industrial valves

9.8.2 When specified in the purchase order, valves shall be fugitive emission production tested. The production fugitive emission testing of valves shall conform to ISO 15848-2.

10 EXTERNAL SURFACE TREATMENT

10.1 Valves shall be delivered, externally sandblasted and primed in accordance with the Manufacturer's standard painting specifications.

10.2 Manufacturer will submit the painting specification for Purchaser's approval.

11 MARKING

11.1 Each valve accepted shall be marked visibly and permanently in a suitable position. The marking shall include the following information:

- Project Mark
- Purchase Order/Contract Number
- Manufacturer's Mark

Reviewed By	Ajique Ur Rehman AE (R&D Transmission)	Mehboob Ali Manager (Transmission)
Approved By	A/SGM (TS)	A/SGM (Transmission)

Signature





- Diameter
- Pressure Rating
- Inspector's Stamp
- Traceability number

11.2 Butt-Welding (BW) ends shall be marked with material designation.

12 DOCUMENTS

12.1 Prior to starting manufacture, the Manufacturer shall submit the following documents and receive written acceptance from the Purchaser:

- Controller Copy of Quality Control Manual
- Welding Procedures
- Pressure Test Procedures
- Non-Destructive Test Procedures
- Drawings
- Inspection Test Plan
- Material Test Certificate
- Boiler and Pressure Vessel Safety Registration Certificate

12.2 Quality Control Program

12.2.1 The manufacturer shall provide documentation with the bidding documents for the in house quality control program which is strictly adhered to for the production of all manufactured equipment. This program must adhere to an internationally accepted quality control standard such as ISO 9000 series and API Spec Q1.

12.2.2 Failure to provide certification of proof of compliance may result in rejection of the bid.

12.2.3 The Supplier shall submit six copies of Inspection and Material Test Certificates to the Purchaser prior to delivery or with delivery of material. The Purchaser has right to reject the consignment if bidder has failed to provide MTC.

12.3 Six copies of the following documents shall be submitted four weeks before the delivery of the valves:

- Scale drawings with parts lists and material data
- Installation, operation and maintenance instructions for the complete valve
- Inspection test and material certificates
- Data sheets and diagrams showing adjustments and closing times.

Reviewed By	Atique-ur-Rehman AE (P&D Transmission) 	Mehboob Ali Manager (Transmission)
Approved By	A/SGM (TS) 	A/SGM (Transmission)





- Calculation sheets
- Description of manufacturing and test procedures

12.4 All documents must be reproducible and suitable for microfilming. Any deviations from the approved specifications must be approved by the Purchaser. The Supplier must submit a detailed test program of the tests to be carried out on the valves which must be subject to review of the Purchaser.

12.5 Six copies of the test documents of each valve in accordance with the requirements of API 6D shall be supplied to the Purchaser. Each such document shall clearly identify the valve to which the document relates.

12.6 Bidders shall include in their bids spare parts recommended for two years operation separately. However, the spare parts for commissioning purpose should be included with valve quotation (if required).


12.7 Final Documentation

12.7.1 A dossier shall be compiled concurrently with full record of the fabrication, materials, inspection and testing.

12.7.2 All items in the dossier shall be numbered and bound in an A4 four post binder; contents shall include but not be limited to the following (as applicable):

- Front cover sheet detailing:
 - P.O. No.
 - Project Title
 - Equipment Title
 - Equipment Item No.
- Index
- Purchaser Release Note
- Purchase Order
- A list of all applicable codes, standards and specifications
- All drawings "As-built" wherever legibility can be preserved, reduced to A4 and folded, where legibility cannot be preserved, drawings to be folded to A4 size and inserted into pre-punched plastic wallets.
- NDT procedures
- All NDT / PWHT / Hydrostatic / Performance test reports
- Photocopy of Nameplate
- Material chemical analysis and mechanical test certification

Reviewed By	Atique Ur Rehman AE (P&P Transmission)	Mehboob Ali Manager (Transmission)
Approved By	A/SGM (TS)	A/SGM (Transmission)



Sub:



- Final signed quality plan
- Material test certificates
- Mechanical design calculations
- Procedure Qualification Records
- Welding qualification Tests
- Painting inspection certificates
- Manufacturing Data Records (MDR)
- Installation Drawings and Procedures
- Operation and Maintenance Manual
- Schedule of commissioning spare parts

12.7.3 For all above documents, six (06) sets shall be submitted in clearly labeled 4 ring white hard cover binders. All documents smaller and larger than A4 shall be inserted into A4 pre-punched, top opening plastic wallets with the project document number/title block clearly visible to the front.

13 LUBRICANT

Type of lubricant/sealant recommended and lubricant/sealant injection hand guns should be specified and prices quoted. The manufacturers shall have in-house know-how and manufacturing facilities of lubricant/sealant used in the offered valves.

14 INSPECTION CERTIFICATES


14.1 The Supplier shall cause inspection certificates to be issued and certified by an inspector of his own quality assurance department appointed for this purpose.

14.2 Each such certificate shall show the results of tests made under these specifications such as tests of the functions of the valves to be supplied and correct dimensions and shall show the Purchaser's Contract Number.

15 PACKING

15.1 All valves shall be assembled prior to shipment and shall be ready for installation upon delivery. The valve shall be so packed, transported and stored as to prevent damage prior to delivery. The Supplier shall warrant that the valves will remain clean and dry during transportation and storage until installation.


Reviewed By	Atique Ur Rehman AE (P&D Transmission) 	Mehboob Ali Manager (Transmission)
Approved By	A/SGM (TS) 	A/SGM (Transmission)





- 15.2 All handling, loading and unloading shall be done in such a manner as to minimize mechanical damage.
- 15.3 Packing shall be sufficiently robust to withstand rough handling during ocean shipment and in-country journey. All items shall have their respective identification letters or numbers painted on body and these shall be suitably packed to provide ease of handling and storage and maximum protection during transport and storage periods. Crates or boxes shall have a list of items contained therein secured to the exterior by means of an enveloping piece of tin sheet nailed to the wood. A duplicate list shall also be included inside with the contents.
- 15.4 Protection against corrosion/deterioration shall be given special attention. Machined steel and iron parts shall be heavily greased/varnished as a preventive measure against rust and where grease is used it shall be such that it retains its consistency, and does not melt at tropical temperatures and is acid free.
- 15.5 Valves shall be shipped with the faces of the flanges or the welding ends protected over the entire contact surfaces with suitable protectors securely attached to the valves. Hand wheels/wrenches shall be packed separately.

Reviewed By	Atique Ur Rehman AE (P&D Transmission)	Mehboob Ali Manager (Transmission)
Approved By	A/SGM (TS)	A/SGM (Transmission)



TERMS OF REFERENCE


Annexure-IV

INSPECTION OF LUBRICATED PLUG VALVES/ FULL BORE BALL VALVES/SWING CHECK VALVES

Third party inspection will be carried out as per attached Specification compliance sheet to witness the manufacturing process including following:


The following test/ points mentioned below, are mandatory and TPI to submit report.

1. Reference applicable Code/Standards/ documents:
 - Drawing & Test Procedure
 - Manufacturer ITP
 - API 6D (Specification for Ball, Check and Plug valves for pipeline service).
 - ANSI/ASME B 31.3, Gas Transmission and Distribution Piping Systems
 - MSS SP-55
 - MSS SP-25
 - ASME BPVC Code
 - ASME B16.5
 - API 598
 - API 599
 - ANSI B 16.20 & 16.11
 - ANSI B 2.1
 - API 6FA
 - API 607
 - API 6FD
2. The valves shall be inspected and tested for the following items as minimum requirement and in accordance with API 598 and other applicable codes.
 - Appearance inspection
 - Visual inspection to be carried out before Hydro test.
 - Dimensional Inspection
 - Functional/operational test
 - Antistatic Device Test
3. All inspection/testing equipment shall be calibrated and their certificate should be available.
4. Material test certificates to be check according to datasheet of valves.
5. EN 3.1 MTC's contain at least RT Reports, Painting reports, Hardness Report.



6. All parts of valves should be brand new, rust free and weld deposit material is not acceptable.
7. Welding and Nondestructive testing to be performed as specified in valves specifications.
8. Both inside and outside surfaces of casting material shall be free from harmful blowholes, fins, seizures of sand scales, sand inclusions and cracks and shall be in accordance with MSS-SP- 55.
9. Trunnion mounted and floating ball valves, Plug valves, Piston, swing check and dual plate wafer check valves, shall be pressure tested in accordance with API 598 and BS6755. Hydrostatic testing shall covers Shell test, Seat Closure test, High Pressure Pneumatic seat Closure test and Low pressure Pneumatic seat test.
10. Fire type-testing shall be in accordance with API 6FA or API 607 as applicable. All valves offered shall be qualified by applicable fire test certification, details of which shall be available for Purchaser review, if requested.
11. U-stamp to be verified for Valve actuators.
12. Valve gear shall be sand blasted and coated or painted in accordance with the manufacturer's standard specifications.
13. Torque testing to be performed as per values provided in specifications.
14. Preservation & Packing checks to be performed as per specifications.
15. Upon completion of satisfactory testing all components to be thoroughly drained and dried prior to preparation for packing.
16. All testing procedure of Assorted Valves shall be 100% witnessed by SSGC's Executives with SSGC's nominated third party inspector as per Pre-shipment Third Party Inspection & Testing Document.

Ahmed



SUI SOUTHERN GAS COMPANY LIMITED

UNDERTAKING OF COMPLIANCE WITH INTEGRATED MANAGEMENT SYSTEM (IMS) MANUAL AND BLACKLISTING MECHANISM

I, _____ [Supplier's Authorized Representative Full Name], of _____ [Supplier Company Name], with principal _____ office located _____ at _____ [Full Address], do hereby solemnly affirm and declare as follows:

1. That I am the duly authorized representative of _____ [Supplier Company Name], and have the legal authority to make this declaration on behalf of the company.
2. That I confirm having accessed, read, and fully understood the **Integrated Management System (IMS) Manual** provided by Sui Southern Gas Company Limited (SSGC), available at the official website <https://www.ssgc.com.pk/web/wp-content/uploads/2025/06/IMS-Manual-1-1.pdf>
3. That _____ [Supplier Company Name] agrees to comply fully with the policies, procedures, and responsibilities outlined in the IMS Manual, and will ensure that all relevant employees, contractors, and agents are made aware of and comply with the same.
4. That _____ [Supplier Company Name] acknowledges that failure to comply with the IMS Manual may result in corrective action, including but not limited to financial penalties as per SSGC policy and suspension or termination of business with Sui Southern Gas Company Limited (SSGC).
5. That the bidder has also read, understood, and accepted the **Blacklisting Mechanism of Sui Southern Gas Company Limited (SSGC)**, available at: https://www.ssgc.com.pk/web/wp-content/uploads/2024/09/blacklisting_mechanism_2024.pdf
6. Any type of violation of the tender terms and non-performance will result in the enforcement of the Blacklisting Mechanism, which will be dealt with in accordance with the Blacklisting Rules/Mechanism.
7. This affidavit is made in good faith and for the purpose of affirming our commitment to health, safety, environmental standards, and compliance with the Integrated Management System (IMS) Manual and the **Blacklisting Mechanism** of Sui Southern Gas Company Limited (SSGC), as well as all other applicable policies and procedures of SSGC.

Signed at _____ [City] on this _____ day of _____, 20__.

Signature: _____
Name: _____
Designation: _____
Company Name: _____
Contact Details: _____

(Company Stamp / Seal Mandatory)

Witnessed by:

Signature of Witness: _____
Name of Witness: _____
Date: _____

Signature of Witness: _____
Name of Witness: _____
Date: _____

