

TECHNICAL EVALUATION REPORT

(As Per Rule 35 of PP Rules, 2004)

- | | |
|--------------------------------|---|
| 1. Name of Procuring Agency | <u>National Grid Company. Ltd (NGC)</u> |
| 2. Method of Procurement | <u>National Competitive Bidding (NCB) & Single Stage Two Envelope (SSTE)</u> |
| 3. Title of Procurement | <u>Supply & Application of Room Temperature Vulcanizing (RTV) Silicone Rubber High Voltage Insulator Coating (HVIC) on AIS Switchyard Equipment at 500kV NKI Grid Station Karachi</u> |
| 4. Tender Inquiry No. | <u>338/DM(GRID)/NKI/NGCP/KHI/2026</u> |
| 5. PPRA Ref No. | <u>TS0000007526E</u> |
| 6. Date & Time of Bid Closing | <u>14/07/2026 at 11:00 A.M.</u> |
| 7. Date & Time of Bid Opening | <u>14/07/2026 at 11:30 A.M.</u> |
| 8. No of Bids Received | <u>02</u> |
| 9. Criteria for Bid Evaluation | <u>Evaluation and Comparison of Bid as per Section-I "Instructions to Bidders" of Bidding Documents</u> |

Name of the Bidders	Technical Mark	Technical Evaluation Result (Responsive/non-responsive)	Remarks
M/s Siddiqui & Associates	NIL	Responsive and recommended for price/financial bid opening	Responsive
M/s CPM (Construction and Project Management Services (p.v.t) LTD.	NIL	Non-Responsive i. Non-compliance with Schedule-A due to incomplete Technical Proposal (IB Clause 25.1). ii. Non-compliance with Schedule-A, Schedule-B and PCC Clause 4.1.5 regarding suitability for site conditions, proposed methodology for RTV application and deployment of key technical staff. iii. Failed to demonstrate the required experience for RTV coating works on 500/220/132kV Switchyards. Only experience related to RTV coating on Transmission Line Insulators was provided, while completion certificates and supporting documents required under Form EXP-1 were not submitted. iv. Manufacturer/Subcontractor supporting experience documents and agreements required under Form EXP-3 and IB Clause 13.4 (Bidder's Qualification Criteria) were not provided. v. Failed to establish the required technical capability and similar project experience as stipulated in the Bidding Documents. vi. FY 2024, and FY 2023 Audited Sheets not provided.	

1. Any other additional/supporting information, the procuring agency may like to share

Nil

Signature _____

Conveyor, Technical Evaluation Committee

Note: The above evaluation results are based on detailed Bid Evaluation Report (BER) and correct to best of our knowledge however, in case of any discrepancy, the content of original BER shall prevail.

Technical Bid Evaluation Results:

Page 1 of 1