



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan

Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

1	OF	3
RFQ No	OP-19765YP	
DATE	02.07.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)

SAP No.6100017203

Company PSO Dummy Vendor PAKISTAN	QUOTATION REQUIRED		
	ON (Date)	17.07.2026	BY (Time)

Please quote your best price for all items of following specifications. Please read the instructions attached herewith **EARNEST MONEY %** Rs. _____ **PO/DD NO.** _____

Title: Supply of Polyamide and Polyurethane Protective Coating for Vertical Tank # 2601 (Roof, Safety Railing <(>&<)> Splash Plates) 2605 (Safety Railing)

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
1	<p><u>EPOXY PRIMER FOR TANKS</u></p> <p>Protective Coating Specification =====</p> <p>.,Type: Two-component High Build Epoxy primer Mastic Coating, Polyamide Cured</p> <p>.,Colour: Grey</p> <p>.,Volume Solids: Minimum 80% by volume</p> <p>.,Flash Point: Minimum 25°C</p> <p>.,Mixing Ratio: 1:1 (Base to Hardener by Volume)</p> <p>.,Application Method: Brush, Roller, or Airless Spray</p> <p>.,Dry Film Thickness (DFT): 100#200 Microns per Coat</p> <p>.,Wet Film Thickness (WFT): 125#250 Microns per Coat</p> <p>.,Surface Preparation Compatibility: Suitable for application on manually or mechanically prepared steel surfaces; recommended for surfaces prepared to St 2 or Sa 2 or equivalent standards.</p> <p>.,Temperature Resistance: Minimum 120°C under continuous dry service conditions.</p> <p>.,Adhesion Properties: Suitable for carbon steel and compatible with properly prepared existing coating systems.</p> <p>.,Packaging: Supplied as matched Base and Hardener components for on-site mixing.</p> <p>.,Shelf Life: Minimum 12 months in original unopened containers.</p> <p>.,Documentation: Manufacturer shall provide Technical Data Sheet, Safety Data Sheet, and product quality certification.</p>	<u>Faqirabad</u> <u>(Depot)</u>	<u>L</u>	130.000		
2	<p><u>PAINT Clifton sand</u></p> <p>Topcoat Paint Specification</p> <p>.,Type: Two-Component Aliphatic Acrylic Polyurethane Coating</p> <p>.,Colour: Light Sand Shade / Beige Tone</p> <p>.,Volume Solids: 63% ± 2% by Volume</p> <p>.,Gloss Level: 70#85 GU at 60° Angle</p> <p>.,Flash Point: Minimum 30°C</p> <p>.,Density: Approximately 1.4 kg/L</p>	<u>Faqirabad</u> <u>(Depot)</u>	<u>L</u>	140.000		



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan

Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

2	OF	3
RFQ No	OP-19765YP	
DATE	02.07.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)

SAP No.6100017203

Company PSO Dummy Vendor PAKISTAN	QUOTATION REQUIRED		
	ON (Date)	17.07.2026	BY (Time)

Please quote your best price for all items of following specifications. Please read the instructions attached herewith **EARNEST MONEY %** Rs. _____ **PO/DD NO.** _____

Title: Supply of Polyamide and Polyurethane Protective Coating for Vertical Tank # 2601 (Roof, Safety Railing <(>&<)> Splash Plates) 2605 (Safety Railing)

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
	<p>.,Dry Film Thickness (DFT): 50#100 Microns per Coat .,Wet Film Thickness (WFT): 80#160 Microns per Coat .,Theoretical Spreading Rate: 6.3#12.6 m²/L (depending on DFT) .,Application Method: Brush, Roller, or Airless Spray .,Surface Compatibility: Suitable for application over properly cured and prepared epoxy primer/intermediate coating systems. .,Weather Resistance: Excellent resistance to UV radiation, atmospheric exposure, and color fading. .,Chemical Resistance: Good resistance to industrial and marine environments. .,Packaging: Supplied as Base and Curing Agent components for on-site mixing. .,Shelf Life: Minimum 12 months in original unopened containers. .,Documentation: Manufacturer shall provide Technical Data Sheet, Safety Data Sheet, and quality certification.</p> <p>TERMS & CONDITIONS =====</p> <p>1.,All quoted rates shall be inclusive of applicable taxes, duties, transportation, and delivery charges. 2.,Quality is of prime importance. The contractor shall supply materials of the highest quality, subject to inspection and approval by the Engineer-in-Charge. 3.,The contractor shall ensure that all supplied materials are genuine, traceable to the original manufacturer, and sourced from fresh stock. 4.,Any material found damaged, defective, or non-conforming at the time of delivery or inspection shall be replaced by the contractor at no additional cost. 5.,In case of delay in completion of the work beyond the stipulated completion period, a penalty of 0.1% of the Work Order value per day shall be imposed, subject to a maximum of 10% of the total Work Order value. 6.,The contractor shall submit the invoice only after obtaining the Work Completion Certificate from the concerned location. 7.,All materials shall be supplied and delivered to PSO Depot,</p>					



Pakistan State Oil Company Limited

PSO House, Khayaban-e-Iqbal, Clifton, Karachi-75600, Pakistan

Telephone (021) 9203866-85 Fax (021) 9203796

PAGE

3	OF	3
RFQ No	OP-19765YP	
DATE	02.07.2026	

REQUEST FOR QUOTATION

(THIS IS PRICE ENQUIRY-NOT AN ORDER)

SAP No.6100017203

Company PSO Dummy Vendor
PAKISTAN

QUOTATION REQUIRED

ON
(Date)

17.07.2026

BY
(Time)

Please quote your best price for all items of following specifications. Please read the instructions attached herewith Rs. _____ EARNEST MONEY %
PO/DD NO. _____

Title: Supply of Polyamide and Polyurethane Protective Coating for Vertical Tank # 2601 (Roof, Safety Railing <(>&<)>
Splash Plates) 2605 (Safety Railing)

S.No.	Description/Specifications	Location	Unit	Qty	Unit Price Rs.	Amount Rs.
	<p>Faqirabad.</p> <p>8.,,The work/supply completion period shall be 25 calendar days from the date of issuance of the Work Order.</p> <p>9.,,The contractor shall provide documentary evidence of procurement from the manufacturer or authorized distributor/dealer. Materials supplied without valid proof of origin may be rejected.</p> <p>10.,,PSO reserves the right to inspect, verify, and reject any material that does not comply with the approved specifications and quality requirements.</p> <p>11.,,Payment shall be processed as per PSO's standard payment terms after satisfactory completion of work/supply and submission of all required documents.</p>					